


EENS Facility Risk Assessment

The only official copy of this file is the one on-line. Before using a printed copy, verify that it is the most current version by checking the document issue date on the EENS OHSAS web site.

Name(s) of Risk Team Members: R. Costa, L. Gerlach, J. Madaia	Point Value → Parameter ↓	1	2	3	4	5
Area/Facility Description Title: Building 185 Facility Risk Assessment	Occupancy or Use (A)	≤once/year	≤once/month	≤once/week	≤once/shift	>once/shift
FRA #: EENS-FRA-185 Rev.#: 0						
Area/Facility Description: Bldg. 185 - Indoor and Outdoor Area	Severity (B)	First Aid Only	Medical Treatment	Lost Time	Partial Disability	Death or Permanent Disability
Approved by:  Date: 2/12/08 Linda Bowerman	Likelihood (C)	Extremely Unlikely	Unlikely	Possible	Probable	Multiple
Reason for Revision (if applicable):				Comments: Limited accessibility to handicap people inside building		

Physical Item or Activity	Hazard(s)	Control(s)	Risk with Controls in Place				Control(s) Added to Reduce Risk	Risk with Additional Controls in Place				% Risk Reduction
			Occupancy A	Severity B	Likelihood C	Risk* AxBxC		Occupancy A	Severity B	Likelihood C	Risk* AxBxC	
General Facility Admin. Activities	General Administrative Building Hazards	See EENS-FRA-001 located at: http://www.bnl.gov/eens/resops/FRA_List.asp	-	-	-	-						
Bldg. 185 Outdoor Area												
Blind spot - SW corner of building.	Injury from auto accident or pedestrian/ auto accident due to limited visibility	Individual caution while driving around corner of building; pedestrian awareness when exiting building	5	1	3	15	Install signs to restrict traffic flow to one way; post Caution Sign to inside door	5	1	2	10	33%
Bldg. 185 Indoor Area												
Handicap chair lift (lift is only handicapped accessible exit for chair bound)	Injury to chair bound due to inability to exit building during loss of power (lift is only handicapped accessible exit)	Posting, fire/rescue awareness - LEP & run card	1	3	1	3						

EENS Facility Risk Assessment

The only official copy of this file is the one on-line. Before using a printed copy, verify that it is the most current version by checking the document issue date on the EENS OHSAS web site.

			Risk with Controls in Place				Risk with Additional Controls in Place					
Physical Item or Activity	Hazard(s)	Control(s)	Occupancy A	Severity B	Likelihood C	Risk* AxBxC	Control(s) Added to Reduce Risk	Occupancy A	Severity B	Likelihood C	Risk* AxBxC	% Risk Reduction
Interior handicap accessibility	Potential injury to handicap people from section doors	Assistance by Building Staff as needed	5	2	1	10						
Further Description of Controls Added to Reduce Risk:												
*Risk:	0 to 20 Negligible	21 to 40 Acceptable	41-60 Moderate				61 to 80 Substantial		81 or greater Intolerable			