

**EMERGENCY SERVICES DIVISION
PROCEDURE

BROOKHAVEN NATIONAL LABORATORY**

Procedure No. FR-GEN-7.0.1

Revision No. 2

Page 1 of 2

Title: Plectron Emergency Radio Warning System Notification

1.0 PURPOSE:

- 1.1 This procedure outlines the notifications to be made when receiving any Plectron transmission during regular work hours (0830 - 1700).
- 1.2 The Plectron Emergency Radio Warning System is part of the Laboratory Emergency System and is capable of transmitting in three modes.

2.0 RESPONSIBILITIES:

- 2.1 The Housewatch is responsible to make these notifications.

3.0 DEFINITIONS:

4.0 PREREQUISITES:

5.0 PRECAUTIONS:

6.0 PROCEDURE

The Plectron Emergency Warning System transmits in the following modes:

- 6.1 A general call (code 99): Notify the Duty Captain and/or the Fire Chief and make pager notifications.
- 6.2 A zone call (codes 1 thru 17): Notify the Duty Captain and/or the Fire Chief and make pager notifications.
- 6.3 Emergency Responders call (code 30) . Page all pager users.

PREPARED BY:

C. LaSalla

Author/Date

Filing Code:

FR20SR.01

REVIEWED BY:

M. Carroll

Chief/Date

J. Vaz

Division QAC/Date

APPROVED BY:

F. Marotta

Division Manager/Date

EFFECTIVE DATE:

Review Cycle: 3 years _____

7.0 IMPLEMENTATION AND TRAINING:

EMERGENCY SERVICES DIVISION PROCEDURE BROOKHAVEN NATIONAL LABORATORY	Procedure No. FR-GEN-7.0.1
Procedure Title: Plectron Emergency Radio Warning System Notification	Revision No. 2 Page 2 of 2

8.0 REFERENCES:

9.0 ATTACHMENTS: