

# Water Quality

Wastewater generated from Brookhaven National Laboratory operations is discharged to surface waters via the Sewage Treatment Plant (STP) and to groundwater via recharge basins. Some wastewater may contain very low levels of radiological, organic, or inorganic contaminants. Monitoring, pollution prevention, and vigilant operation of treatment facilities ensure that these discharges comply with all applicable requirements and that the public, employees, and environment are protected.

Analytical data for 2005 show that the average gross alpha and beta activity levels in the STP discharge were within the typical range of historical levels and were well below drinking water standards. Tritium releases to the Peconic River continued to decline and were the lowest ever recorded. The maximum concentration of tritium released was approximately 3.5 percent of the drinking water standard. Analysis of the STP effluent continued to show no detection of cesium-137 or other gamma-emitting nuclides attributable to BNL operations. Strontium-90 detected in a single sample of influent was at a level similar to upstream and other background locations, and was not detected in the effluent. Very low concentrations of tritium were occasionally detected at the STP outfall, but tritium was only detected once at the first downstream monitoring station (HM-N). No other nuclides were detected downstream of the STP discharge.


Nonradiological monitoring of effluent showed that, except for isolated incidents of noncompliance, organic and inorganic parameters were within State Pollutant Discharge Elimination System effluent limitations or other applicable standards. Inorganic data from Peconic River samples collected upstream, downstream, and at control locations demonstrated that elevated amounts of aluminum and iron detected in the river were a result of natural sources.

## 5.1 SURFACE WATER MONITORING PROGRAM

Treated wastewater from the BNL Sewage Treatment Plant is discharged into the headwaters of the Peconic River. This discharge is permitted under the New York State Department of Environmental Conservation (NYSDEC) State Pollutant Discharge Elimination System (SPDES) Program. Effluent limits are based on the water quality standards established by NYSDEC, as well as historical operational data. To assess the impact of wastewater discharge on the quality of the river, surface water is monitored at several locations upstream and downstream of the discharge point. Monitor-

ing Station HY (see Figure 5-8), on site but upstream of all Laboratory operations, provides information on the “background” water quality of the Peconic River. The Carmans River is monitored as a geographic control location for comparative purposes, as it is not affected by operations at BNL.

On the Laboratory site, the Peconic River is an intermittent stream. Off-site flow occurs only during periods of sustained precipitation, typically in the spring. Off-site flow was recorded from January through June, then again from October through December. October was the wettest month recorded on site, with 22 inches of rain; this resulted in high off-site flows dur-



**Figure 5-1. Schematic of BNL's Sewage Treatment Plant (STP).**

ing the latter part of the year. The following sections describe the Laboratory's surface water monitoring and surveillance program.

## 5.2 SANITARY SYSTEM EFFLUENTS

The STP effluent (Outfall 001) is a discharge point operated under a SPDES permit issued by NYSDEC. Figure 5-1 shows a schematic of the STP and its sampling locations. The Laboratory's STP treatment process includes five steps: 1) primary clarification to remove settleable solids and floatable materials, 2) aerobic oxidation for secondary removal of biological matter and nitrification of ammonia, 3) secondary clarification, 4) sand filtration for final solids removal, and 5) ultraviolet disinfection for bacterial control prior to discharge to the Peconic River. Tertiary treatment for nitrogen removal also is provided by controlling the oxygen levels in the aeration tanks. During the aeration process (i.e., Step 2), the oxygen levels are allowed to drop to the point where microorganisms use nitrate-bound oxygen for respiration; this liber-

ates nitrogen gas and consequently reduces the concentration of nitrogen in the STP discharge.

Nitrogen is an essential nutrient in biological systems that, in high concentrations, can cause excessive aquatic vegetation growth. During the night (when photosynthesis does not occur), aquatic plants use oxygen in the water. Too much oxygen uptake by aquatic vegetation deprives a water system of oxygen needed by fish and other aquatic organisms for survival. Limiting the concentration of nitrogen in the STP discharge helps keep plant growth in the Peconic River in balance with the nutrients provided by natural sources.

Real-time monitoring of the sanitary wastewater stream for radioactivity, pH, and conductivity takes place at two locations. The first site (MH-192, see Figure 5-1) is approximately 1.1 miles upstream of the STP, providing at least 30 minutes' warning to the STP operators if wastewater is en route that may exceed SPDES limits or BNL effluent release criteria (which are more stringent than DOE-specified levels). The sec-

ond site is at the point where the STP influent enters the primary clarifier, as shown in Figure 5-1. In addition to the monitoring that occurs at these two stations, as effluent leaves the primary clarifier it is also monitored for radioactivity.

Based on the data collected by the real-time monitoring systems, any influent to the clarifier that may not meet SPDES limits or BNL effluent release criteria (whichever is more stringent) is diverted to two double-lined holding ponds. The total combined capacity of the two holding ponds exceeds 7 million gallons, or approximately 21 days of flow. Diversion continues until the effluent's water quality meets the permit limits or release criteria. If wastewater is diverted to the holding ponds, it is tested and evaluated against the requirements for release. If necessary, the wastewater is treated, then reintroduced into the STP at a rate that ensures compliance with SPDES permit limits for nonradiological parameters or BNL effluent release criteria for radiological parameters. In 2005, the STP influent was diverted in October due to increased flow that occurred during very heavy rains. Influent flow rates, that peaked at 2.8 million gallons per day, could have resulted in inadequately treated waste, violating the Laboratory's SPDES permit. The excess flow was bypassed to the holding ponds and held for treatment after the peak flow period subsided.

Solids separated in the clarifiers are pumped to an aerobic digester for solids reduction. Sludge is periodically emptied into solar/heat lamp-powered drying beds, where it is dried to a semisolid cake. The dried sludge contains very low levels (less than 0.5 pCi/g) of radioactivity, such as residual levels of cobalt-60 (Co-60: half-life 5.2 years) from historic sewage releases. The dried sludge is put into containers for off-site disposal at an authorized facility.

#### 5.2.1 Sanitary System Effluent–Radiological Analyses

Wastewater at the STP is sampled at the output of the primary clarifier, Station DA (see Figure 5-2) and at the Peconic River Outfall (Station EA). At each location, samples are collected on a flow-proportional basis; that is, for every 1,000 gallons of water treated, approximately 4 fluid

ounces of sample are collected and composited into a 5-gallon collection container. These samples are analyzed for gross alpha and gross beta activity and for tritium concentrations. During 2005, samples were collected three times weekly. Samples collected from these locations are also composited and analyzed monthly for gamma-emitting radionuclides and strontium-90 (Sr-90: half-life 29 years).

Although the Peconic River is not used as a direct source of potable water, the Laboratory applies the stringent Safe Drinking Water Act (SDWA) standards for comparison purposes when monitoring the effluent, in lieu of DOE wastewater criteria. EPA revised the SDWA limits for radionuclides in 2003. Under the revisions, the gross activity limit for beta emitters (50 pCi/L) was replaced with a 4 mrem (40  $\mu$ Sv) dose limit. The SDWA specifies that no individual may receive an annual dose greater than 4 mrem from radionuclides that are beta or photon emitters. Beta/photon emitters include up to 168 individual radioisotopes. The Laboratory performs radionuclide-specific gamma analysis to ensure compliance with this standard. The SDWA annual average gross alpha activity limit is 15 pCi/L, including radium-226 (Ra-226: half-life 1,600 years) but excluding radon and uranium. Other SDWA-specified drinking water limits are 20,000 pCi/L for tritium (H-3: half-life 12.3 years), 8 pCi/L for Sr-90, 5 pCi/L for Ra-226 and radium-228 (Ra-228: half-life 5.75 years), and 30  $\mu$ g/L for uranium. Gross activity (alpha and beta) measurements are used as a screening tool for detecting the presence of radioactivity. Table 5-1 shows the monthly gross alpha and beta activity data and tritium concentrations for the STP influent and effluent during 2005. Annual average gross alpha and beta activity levels in the STP effluent were  $0.3 \pm 0.1$  pCi/L and  $4.6 \pm 0.3$  pCi/L, respectively. Control location data (Carmans River Station HH; see Figure 5-8 for location) show average gross alpha and beta levels of  $0.4 \pm 0.2$  pCi/L and  $1.9 \pm 1.2$  pCi/L, respectively (see Table 5-7).

Tritium detected at the STP originates from either High Flux Beam Reactor (HFBR) sanitary system releases, or from small, infrequent batch releases from other facilities that meet BNL dis-

# CHAPTER 5: WATER QUALITY

Table 5-1. Tritium and Gross Activity in Water at the BNL Sewage Treatment Plant.

		Flow (a) (Liters)	Tritium (pCi/L)		Gross Alpha (pCi/L)		Gross Beta (pCi/L)	
			max.	avg.	max.	avg.	max.	avg.
January	influent	2.94E+7	470 ± 190	88 ± 88.9	3.7 ± 2.0	0.9 ± 0.6	15.1 ± 2.2	6.4 ± 1.7
	effluent	2.83E+7	< 240	57.9 ± 62	< 1.4	0.2 ± 0.2	6.9 ± 1.6	5.3 ± 0.7
February	influent	2.62E+7	1180 ± 310	153.3 ± 192.3	2.1 ± 1.2	0.3 ± 0.4	8.7 ± 1.3	6.3 ± 0.6
	effluent	2.81E+7	< 270	1.7 ± 62.6	2.8 ± 1.7	0.7 ± 0.5	6.9 ± 1.6	5.8 ± 0.4
March	influent	3.33E+7	340 ± 180	94.6 ± 59.3	< 1.9	0.4 ± 0.3	6.7 ± 1.6	5.7 ± 0.5
	effluent	3.37E+7	290 ± 180	91.1 ± 68.4	< 1.6	0.3 ± 0.2	7.8 ± 1.6	5.6 ± 0.7
April	influent	3.72E+7	< 300	-12.2 ± 57.4	< 2.1	0.5 ± 0.2	7.1 ± 1.6	5.3 ± 0.6
	effluent	3.96E+7	< 300	-30.6 ± 28.9	< 1.6	0.3 ± 0.2	6.7 ± 1.5	4.9 ± 0.4
May	influent	3.96E+7	< 220	-45.4 ± 51.6	< 2.0	0.5 ± 0.3	5.9 ± 1.4	4.7 ± 0.4
	effluent	4.33E+7	< 220	-9.3 ± 51	< 1.5	0.2 ± 0.2	5.3 ± 1.4	4.5 ± 0.3
June	influent	5.16E+7	< 350	69.2 ± 67.3	6.9 ± 1.4	1.0 ± 1.0	5.5 ± 1.0	4.2 ± 0.5
	effluent	5.13E+7	< 240	79.8 ± 30	1.7 ± 1.2	0.3 ± 0.3	4.9 ± 1.4	4.2 ± 0.2
July	influent	5.43E+7	730 ± 240	256.7 ± 132.4	1.3 ± 0.9	0.3 ± 0.3	6.0 ± 1.2	4.4 ± 0.4
	effluent	5.14E+7	730 ± 210	249.2 ± 158.2	< 1.7	0.2 ± 0.2	5.1 ± 1.3	4.0 ± 0.6
August	influent	6.47E+7	650 ± 240	118.9 ± 119.7	< 1.9	0.6 ± 0.1	8.7 ± 1.6	4.7 ± 0.8
	effluent	5.59E+7	600 ± 240	112.9 ± 111.6	2.1 ± 1.4	0.4 ± 0.3	7.3 ± 1.2	4.9 ± 0.5
September	influent	5.11E+7	< 320	88.3 ± 60.8	2.2 ± 1.2	0.4 ± 0.3	5.2 ± 1.4	4.4 ± 0.4
	effluent	4.21E+7	< 300	121.3 ± 65.1	< 1.5	0.1 ± 0.2	5.0 ± 1.5	4.0 ± 0.4
October	influent	5.12E+7	< 430	48.2 ± 64.3	3.1 ± 1.4	0.9 ± 0.4	5.4 ± 1.5	4.1 ± 0.4
	effluent	6.07E+7	< 360	51.5 ± 34.9	5.1 ± 1.8	0.9 ± 0.7	7.0 ± 2.4	4.3 ± 0.7
November	influent	4.08E+7	< 350	-76.7 ± 112.8	1.5 ± 1.0	0.6 ± 0.3	7.0 ± 1.5	5.0 ± 0.9
	effluent	3.38E+7	< 380	0.5 ± 72.1	< 1.6	0.1 ± 0.2	11.3 ± 1.6	5.0 ± 1.4
December	influent	3.94E+7	2490 ± 400	245.3 ± 369.6	< 2.6	0.5 ± 0.2	7.1 ± 1.6	3.9 ± 1.0
	effluent	3.90E+7	< 340	109.5 ± 65.1	< 1.5	0.0 ± 0.6	6.4 ± 1.5	2.4 ± 3.2
Annual Avg.	influent			85.5 ± 42.9		0.6 ± 0.1		4.9 ± 0.2
	effluent			69.6 ± 24		0.3 ± 0.1		4.6 ± 0.3
Total Release		5.07E+8		35.8 mCi		0.2 mCi		2.1 mCi
Average MDL (pCi/L)			307.5		1.7		1.9	
SDWA Limit (pCi/L)			20,000		15		(b)	

## Notes:

All values are reported with a 95% confidence interval.  
Negative numbers occur when the measured value is lower than background (see Appendix B for description).

To convert values from pCi to Bq, divide by 27.03.

MDL = Minimum Detection Limit

SDWA = Safe Drinking Water Act

- (a) Effluent values greater than influent values occur when water that had been diverted to the holding ponds is tested, treated (if necessary), and released.  
(b) The drinking water standards were changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in late 2003. As gross beta activity does not identify specific radionuclides, a dose equivalent cannot be calculated for the values in the table.

charge criteria. Although the HFBR is no longer operating, tritium continues to be released from the facility at very low concentrations, due to off-gassing. When the HFBR was operating, air within the reactor building contained higher levels of tritium in the form of water vapor. The water was absorbed by many porous surfaces and materials, which slowly liberate the tritiated moisture as it is replaced by untritiated water. Once tritium is in the air stream, it condenses as a component of water vapor in the air conditioning or air compressor units and is discharged in these wastewater streams. To minimize the quantity of tritium released to the STP, efforts have been made to capture most of the air conditioning condensate collected on the equipment level of the HFBR. A plot of the 2005 tritium concentrations recorded in the STP effluent is presented in Figure 5-2. A 15-year trend plot of annual average tritium concentrations measured in the STP discharge is shown in Figure 5-3. The annual average concentration trend has been declining since 1995.

In 2005, a total of 0.04 Ci of tritium was released during the year (see Figure 5-4). The annual average tritium concentration as measured in the STP effluent (EA, Outfall 001) was  $70 \pm 24$  pCi/L, which is approximately 20 percent less than that recorded for 2004 and well below the drinking water standard (DWS) of 20,000

pCi/L. The 2005 value is approximately one-quarter the average minimum detection limit (MDL) of 307 pCi/L. The maximum concentration detected in the STP discharge (see Figure 5-2) was  $730 \pm 210$  pCi/L. Evaporative losses are expected to be greatest during the warmer months; consequently, tritium was detected above the MDL in samples collected from June through August, when discharges increase due to HFBR air conditioning condensate. Additionally, work to further ready the HFBR for decommissioning and decontamination, which may have exposed residual moisture within the HFBR piping system, may have contributed to slightly higher summertime tritium releases. These levels should continue to decrease, provided no additional work is conducted that could expose tritium contained in reactor components.

Table 5-2 presents the gamma spectroscopy analytical data for anthropogenic radionuclides historically detected in the monthly STP wastewater composite samples. During 2005, there were no gamma-emitting nuclides detected in the STP effluent, which is consistent with the data reported for 2003 and 2004 (see Figure 5-5). Sr-90 was detected in a single sample of influent collected in May but was not detectable in the effluent. The concentration detected (0.87 pCi/L) was very similar to levels found in upstream portions of the Peconic River.






Figure 5-2. Tritium Concentrations in Effluent from the BNL Sewage Treatment Plant (2005).

**Figure 5-3.**  
Sewage Treatment  
Plant/Peconic  
River Annual  
Average Tritium  
Concentrations  
(1991-2005)



**Figure 5-4.**  
Tritium Released to  
the Peconic River,  
15-Year Trend  
(1991-2005).



**Figure 5-5.**  
Cesium-137 in  
the BNL Sewage  
Treatment Plant  
Influent and Effluent  
(1991-2005).






Table 5-2. Gamma-Emitting Radionuclides and Sr-90 in Water at the BNL Sewage Treatment Plant.

		Flow (Liters)	Co-60	Cs-137	Be-7 (pCi/L)	Na-22	Sr-90
January	<i>influent</i>	2.94E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	2.83E+7	ND	ND	ND	ND	ND
	<i>influent</i>	2.62E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	2.81E+7	ND	ND	ND	ND	ND
March	<i>influent</i>	3.33E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	3.37E+7	ND	ND	ND	ND	ND
April	<i>influent</i>	3.72E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	3.96E+7	ND	ND	ND	ND	ND
May	<i>influent</i>	3.96E+7	ND	ND	ND	ND	0.87 ± 0.38
	<i>effluent</i>	4.33E+7	ND	ND	ND	ND	ND
June	<i>influent</i>	5.16E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	5.13E+7	ND	ND	ND	ND	ND
July	<i>influent</i>	5.43E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	5.14E+7	ND	ND	ND	ND	ND
August	<i>influent</i>	6.47E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	5.59E+7	ND	ND	ND	ND	ND
September	<i>influent</i>	5.11E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	4.21E+7	ND	ND	ND	ND	ND
October	<i>influent</i>	5.12E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	6.07E+7	ND	ND	ND	ND	ND
November	<i>influent</i>	4.08E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	3.38E+7	ND	ND	ND	ND	ND
December	<i>influent</i>	3.94E+7	ND	ND	ND	ND	ND
	<i>effluent</i>	3.90E+7	ND	ND	ND	ND	ND
Total Release to the Peconic River (mCi)			0	0	0	0	0
DOE Order 5400.5 DCG (pCi/L)			5,000	3,000	50,000	10,000	1,000
Dose limit of 4 mrem EDE (pCi/L)			100	200	6,000	400	8

## Notes:

No BNL-derived radionuclides were detected in the effluent to the Peconic River for 2005.

To convert values from pCi to Bq, divide by 27.03.

DCG = Derived Concentration Guide

EDE = Effective Dose Equivalent

ND = Not Detected

Sr-90 = Strontium-90

### 5.2.2 Sanitary System Effluent–Nonradiological Analyses

In addition to the compliance monitoring discussed in Chapter 3, effluent from the STP is also monitored for nonradiological contaminants under the BNL Environmental Surveillance Program. Data are collected for field-measured parameters such as temperature,

specific conductivity, pH, and dissolved oxygen, as well as inorganic parameters such as chlorides, nitrates, sulfates, and metals. Composite samples of the STP effluent are collected using a flow-proportional refrigerated sampling device (ISCO Model 3700RF) and are then analyzed by contract analytical laboratories. Samples are analyzed for 23 inorganic ele-

ments, anions, semivolatile organic compounds (SVOCs), pesticides, and herbicides. In addition, grab samples are collected monthly from the STP effluent and analyzed for 38 different volatile organic compounds (VOCs). Daily influent and effluent logs are maintained by the STP operators for flow, pH, temperature, and settleable solids as part of routine monitoring of STP operations.

Table 5-3 summarizes the water quality and inorganic analytical results for the STP samples. Comparing the effluent data to the SPDES effluent limits (or New York State Ambient Water Quality Standards [NYS AWQS], as appropriate) shows that most of the analytical parameters were within SPDES effluent permit limits (see also the compliance data in Chapter 3). There was one detection of a parameter above its SPDES limit: in November, zinc was detected at 113 ppb, exceeding the permit limit of 100 ppb.

There were single instances, both in February, when aluminum and vanadium exceeded the NYS AWQS. Review of the analytical data report showed that several inorganics were higher than typical levels. The contract analytical laboratory indicated that there was a problem with the analysis (matrix interference); consequently, the results were questionable. All other results were below the applicable limit or guidance value. See Section 5.5 for further discussion of the Peconic River and other surface waters.

Acetone and methylene chloride are periodically detected in the effluent. Both are common solvents and are typically found in background levels in laboratories. The maximum concentrations detected were 4.1 µg/L and 5.0 µg/L, respectively. No other organic compounds were detected above the MDL in 2005. Although there are no SPDES limits or ambient water quality standards specified for acetone, NYS-DEC imposes a generic limit of 50 µg/L for unlisted organic compounds. The amounts detected in BNL samples were approximately 10 percent of that generic limit.

### 5.3 PROCESS-SPECIFIC WASTEWATER

Wastewater that may contain constituents above SPDES permit limits or ambient water

quality discharge standards must be held by the generating facility and be characterized to determine the appropriate means of disposal. The analytical results are compared with the appropriate discharge limit, and the wastewater is released to the sanitary system only if the volume and concentration of contaminants in the discharge would not jeopardize the quality of the STP effluent and, subsequently, the Peconic River.

The Laboratory's SPDES permit includes requirements for quarterly sampling and analysis of process-specific wastewater discharged from printed-circuit-board fabrication operations conducted in Building 535B, metal cleaning operations in Building 498, cooling tower discharges from Building 902, and boiler blow-down from satellite boilers in Buildings 244 and 423. These operations are monitored for contaminants such as metals, cyanide, VOCs, and SVOCs. Analyses of these waste streams in 2005 showed that, although several operations contributed contaminants to the STP in concentrations exceeding SPDES-permitted levels, these discharges did not affect the quality of the STP effluent.

Process wastewaters that were not expected to be of consistent quality because they were not routinely generated were held for characterization before release to the site sewer system. The process wastewaters typically included primary closed-loop cooling water, heat exchanger cleaning wastewater, wastewater generated as a result of restoration activities, and other industrial wastewaters. To determine the appropriate disposal method, samples were analyzed for contaminants specific to the process. The analyses were then reviewed and the concentrations were compared to the SPDES effluent limits and the Laboratory's effluent release criteria. If the concentrations were within limits, authorization for sewer system discharge was granted; if not, alternate means of disposal were pursued. Any waste that contained elevated levels of hazardous or radiological contaminants in concentrations that exceeded Laboratory effluent release criteria was sent to the BNL Waste Management Facility for proper management and offsite disposal.



Table 5-3. BNL Sewage Treatment Plant (STP) Water Quality and Metals Analytical Results.

ANALYTE	Units	STP Influent				STP Effluent				SPDES Limit or AWQS (1)	Comment or Qualifier
		N	Min.	Max.	Avg.	N	Min.	Max.	Avg.		
pH	SU	CM	5.3	10.7	NA	CM	5.8	7.4	NA	5.8 - 9.0	
Conductivity	µS/cm	CM	NR	NR	NR	172 (a)	140	467	302	SNS	
Temperature	°C	CM	NR	NR	NR	172 (a)	1.8	26.6	14.9	SNS	
Dissolved Oxygen	mg/L	NM	NM	NM	NM	172 (a)	6.3	15.4	9.8	SNS	
Chlorides	mg/L	12	37.7	77.0	52.3	12	27.2	62.0	44.1	SNS	
Nitrate (as N)	mg/L	12	0.1	4.4	2.4	6	1.9	8.1	5.6	10	Total N
Sulfates	mg/L	12	12.3	26.9	17.0	12	12.1	17.9	15.9	250	GA
Aluminum	µg/L	12	49.8	295.0	186.5	12	9.3	128.0	49.6	100	Ionic
Antimony	µg/L	12	0.6	< 5	< 5	12	0.7	< 12.5	< 12.5	3	GA
Arsenic	µg/L	12	2.3	5.2	< 5	12	2.5	< 12.5	< 12.5	150	Dissolved
Barium	µg/L	12	9.0	58.1	38.3	12	2.9	33.0	18.5	1000	GA
Beryllium	µg/L	12	< 2	< 2	< 2	12	< 2	< 5	< 5	11	Acid Soluble
Cadmium	µg/L	12	0.1	0.8	0.4	12	0.2	< 2	< 2	1.1	Dissolved
Calcium	mg/L	12	9.2	15.0	11.9	12	9.3	13.0	10.9	SNS	
Chromium	µg/L	12	1.9	8.4	< 5	12	4.1	11.8	< 5	34.4	Dissolved
Cobalt	µg/L	12	0.5	1.7	1.1	12	0.6	< 5	< 5	5	Acid Soluble
Copper	µg/L	12	19.8	151.0	93.9	12	4.9	76.3	34.9	150	SPDES
Iron	mg/L	12	1.1	2.9	1.9	12	0.1	0.3	0.2	0.37	SPDES
Mercury	µg/L	12	0.1	0.6	< 0.2	12	0.1	< 0.2	< 0.2	0.8	SPDES
Manganese	µg/L	12	12.3	59.8	33.5	12	2.8	11.4	5.0	300	GA
Magnesium	mg/L	12	3.0	5.1	4.1	12	2.9	4.0	3.5	SNS	
Nickel	µg/L	12	6.0	20.1	< 0.2	12	2.5	41.1	15.1	110	SPDES
Lead	µg/L	12	1.8	22.5	12.1	12	0.9	5.1	< 3	19	SPDES
Potassium	mg/L	12	2.1	5.8	4.6	12	1.1	10.7	4.4	SNS	
Selenium	µg/L	12	0.6	< 5	< 5	12	0.7	< 12.5	< 12.5	4.6	Dissolved
Silver	µg/L	12	0.2	< 2	< 2	12	2.0	5.8	2.3	15	SPDES
Sodium	mg/L	12	23.3	62.2	41.9	12	16.7	52.6	36.4	SNS	
Thallium	µg/L	12	0.3	< 5	< 5	12	0.5	< 12.5	< 12.5	8	Acid Soluble
Vanadium	µg/L	12	2.6	17.5	7.1	12	1.9	21.0	6.0	14	Acid Soluble
Zinc	µg/L	12	40.2	116.0	78.1	12	30.1	113.0	58.6	100	SPDES

## Notes:

See Figure 5-1 for locations of the STP influent and effluent monitoring locations.

All analytical results were generated using total recoverable analytical techniques.

For Class C AWQS, the solubility state for the metal is provided.

(1) Unless otherwise provided, the reference standard is NYSDEC Class C Surface Water AWQS.

(a) The conductivity, temperature, and dissolved oxygen values reported are based on analyses of daily grab samples.

AWQS = Ambient Water Quality Standards

CM = Continuously monitored

GA = Class GA (groundwater) Ambient Water Quality Standard

N = Number of Samples

NA = Not Applicable

NM = Not Monitored

NR = Not Recorded

NYSDEC = New York State Department of Environmental Conservation

SNS = Standard Not Specified


SPDES = State Pollutant Discharge Elimination System

SU = Standard Units

#### 5.4 RECHARGE BASINS

Recharge basins are used for the discharge of “clean” wastewater streams, including once-through cooling water, stormwater runoff, and cooling tower blowdown. With the exception of elevated temperature and increased natural sediment content, these wastewaters are suitable for direct replenishment of the groundwater aquifer. Figure 5-6 shows the locations of the Laboratory’s discharges to recharge basins (also called “outfalls” under BNL’s SPDES permit). Figure 5-7 presents an overall schematic of potable water use at the Laboratory. Ten recharge basins are used for managing once-through cooling water, cooling tower blowdown, and stormwater runoff:

- Basins HN, HT-W, and HT-E receive once-through cooling water discharges generated at the Alternating Gradient Synchrotron (AGS) and Relativistic Heavy Ion Collider (RHIC), as well as cooling tower blowdown and stormwater runoff.
- Basin HS receives predominantly stormwater runoff, once-through cooling water from Building 555 (Chemistry Department), and minimal cooling tower blowdown from the National Synchrotron Light Source (NSLS).
- Basin HX receives Water Treatment Plant filter backwash water.
- Basin HO receives cooling water discharges from the AGS and stormwater runoff from the area surrounding the HFBR.



**Figure 5-6. BNL Recharge Basin/Outfall Locations.**


- Several other recharge areas are used exclusively for discharging stormwater runoff. These areas include Basin HW in the warehouse area, Basin CSF at the Central Steam Facility, Basin HW-M at the former Hazardous Waste Management Facility (HWMF), and Basin HZ near Building 902. In late 2004, the basin identified as HW-M was removed as remediation of the former HWMF began. This facility was remediated in accordance with its Record of Decision, and the former discharge point was restored through the installation of geotextile topped with rocks to prevent erosion. The remainder of the area was restored to a natural state.

Each of the recharge basins is a permitted point-source discharge under the Laboratory's SPDES permit. Where required by the permit, the discharge to the basin is equipped with a flow monitoring station; weekly recordings of flow are collected, along with measurements of pH. The specifics of the SPDES compliance

monitoring program are provided in Chapter 3. To supplement that monitoring program, samples are also routinely collected and analyzed under BNL's Environmental Monitoring Program for radioactivity, VOCs, metals, and anions. During 2005, water samples were collected from all the basins listed above except basin HX (at the Water Treatment Plant; exempted by NYSDEC from sampling due to documented non-impact to groundwater) and basin HW-M, which is being monitored as part of the remediation of the former HWMF.

#### 5.4.1 Recharge Basins - Radiological Analyses

Discharges to the recharge basins were sampled throughout the year for subsequent analyses for gross alpha and beta activity, gamma-emitting radionuclides, and tritium. These results are presented in Table 5-4. The data show that low levels of alpha and beta activity were detected in most of the basins. Activities ranged from nondetectable to  $4.2 \pm 1.4$  pCi/L for gross alpha activity, and from nondetectable



**Figure 5-7. Schematic of Potable Water Use and Flow at BNL.**

Table 5-4. Radiological Analysis of Samples from On-Site Recharge Basins at BNL.

BASIN		Gross Alpha	Gross Beta	Tritium
		(pCi/L)		
No. of samples		4	4	4
HN	max.	< 1.9	5.1 ± 1.4	< 400
	avg.	0.5 ± 0.5	3.0 ± 1.4	52.5 ± 95.5
HO	max.	1.3 ± 0.8	3.2 ± 1.3	640 ± 230
	avg.	0.5 ± 0.6	1.9 ± 0.9	120 ± 359.4
HS	max.	< 1.4	3.5 ± 1.2	< 390
	avg.	0.5 ± 0.5	2.7 ± 0.9	-25 ± 101.4
HT-E	max.	< 39*	< 36*	< 260
	avg.	3.7 ± 4.2	12.2 ± 8.8	-40 ± 157.4
HT-W	max.	< 1.1	4.5 ± 1.1	< 260
	avg.	0.2 ± 0.5	2.8 ± 1.5	10 ± 173.3
HW	max.	4.2 ± 1.4	6.6 ± 1.5	< 220
	avg.	1.8 ± 1.8	4.5 ± 2.17	27.5 ± 37
HZ	max.	< 5.3	13.1 ± 2.8	< 390
	avg.	1.2 ± 1.3	6.4 ± 4.9	-80 ± 142.0
SDWA Limit		15	(a)	20,000

## Notes:

See Figure 5-6 for the locations of recharge basins.

All values reported with a 95% confidence interval.

Negative numbers occur when the measured value is lower than background (see Appendix B for description).

To convert values from pCi to Bq, divide by 27.03.

MDL = Minimum Detection Limit

SDWA = Safe Drinking Water Act

\*A lower MDL could not be achieved due to high solids content of the sample.

(a) The drinking water standard was changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in late 2003. As gross beta activity does not identify specific

to  $13.1 \pm 2.8$  pCi/L for gross beta activity. Low-level detections of gross alpha and beta activity are attributable to very low levels of naturally occurring radionuclides, such as potassium-40 (K-40; half-life  $1.3 \times 10^9$  years). The contract analytical laboratory reported no gamma-emitting nuclides attributable to BNL operations in any discharges to recharge basins in 2005. Tritium was detected in a single sample collected at Basin HO at very low levels (i.e.,  $640 \pm 230$  pCi/L). This basin receives discharges from the Collider–Accelerator complex and the HFBR.

#### 5.4.2 Recharge Basins–Nonradiological Analyses

To determine the overall impact of the recharge basin discharges on the environment, the nonradiological analytical results were compared to groundwater discharge standards promulgated under Title 6 of the New York Codes, Rules, and Regulations (NYCRR), Part 703.6. Samples were collected quarterly for water quality parameters, metals, and VOCs, and analyzed by a contract analytical laboratory. Field-measured parameters (pH, conductivity, and temperature) were routinely monitored and recorded. The water quality and metals analytical results are summarized in Tables 5-5 and 5-6, respectively.

Low concentrations of disinfection byproducts are periodically detected. Sodium hypochlorite and bromine, used to control algae in cooling towers, lead to the formation of VOCs including bromoform, chloroform, dibromochloromethane, and dichlorobromomethane. In 2005, concentrations ranged from nondetectable to a maximum of 5 µg/L. Acetone and methylene chloride were the only other analytes detected above minimum detection limits for most recharge basins, ranging from nondetectable to a maximum of 20 µg/L. In most instances, acetone and methylene chloride were also found as contaminants in the contract analytical laboratory, as evidenced by detections in blank samples.

The analytical data in Tables 5-5 and 5-6 show that all parameters, except for aluminum, iron, and lead, complied with the respective groundwater discharge or water quality standards. Chlorides were found to be higher in discharge samples collected during the winter and are attributed to road salt used to control snow and ice buildup. Iron and aluminum are natural components of soil and readily dissolve when water samples are acidified for preservation. Iron is also naturally present in Long Island groundwater at concentrations that exceed the New York State groundwater discharge standard (GDS). Filtration of samples resulted in aluminum and iron concentrations that were less than the NYS AWQS or GDS, as appropriate. As the aluminum and iron are in particulate form, they pose no threat to groundwater quality, because the recharge basin acts as a natural filter, trap-

Table 5-5. Water Quality Data for BNL On-Site Recharge Basin Samples.

ANALYTE	No. of samples	Recharge Basin								NYSDEC Effluent Standard	Typical MDL
		HN (RHIC)	HO (AGS)	HS (s)	HT-W (Linac)	HT-E (AGS/HFBR)	HW (s)	CSF (s)	HZ (s)		
		4	4	4	4	4	4	4	4		
pH (SU)	min.	6.9	6.3	7.4	7.2	7.6	7.5	7.1	7.5	6.5 - 8.5	NA
	max.	7.9	7.5	8.0	7.8	7.8	7.8	7.5	7.7		
Conductivity (µS/cm)	min.	177	141	170	136	171	41	59	168	SNS	NA
	max.	362	199	284	191	1006	340	294	782		
	avg.	226	166	216	170	542	132	170	409		
Temperature (°C)	min.	7.3	12.2	2.4	7.1	3.4	4.0	4.5	4.6	SNS	NA
	max.	110.2	19.0	10.9	17.1	12.2	24.9	25.6	21.2		
	avg.	34.3	16.2	7.8	13.5	7.8	12.6	13.8	13.3		
Dissolved oxygen (mg/L)	min.	10.6	9.7	10.7	9.1	9.3	8.3	8.2	8.9	SNS	NA
	max.	11.4	10.8	13.7	11.8	15.1	13.4	12.7	13.6		
	avg.	11.1	10.2	12.2	10.5	12.3	11.4	11.0	11.1		
Chlorides (mg/L)	min.	22.1	19.5	21.0	20.5	31.2	2.4	2.2	29.6	500	4
	max.	62.4	28.7	51.9	40.5	3260.0	22.5	131.0	101.0		
	avg.	37.8	25.1	36.5	29.3	883.2	9.5	46.9	55.8		
Sulfates (mg/L)	min.	10.8	8.0	8.9	10.8	11.6	2.1	2.4	9.7	500	4
	max.	23.4	11.0	15.6	15.9	48.5	7.2	27.4	49.1		
	avg.	14.7	9.8	12.2	12.3	36.7	4.2	9.7	23.8		
Nitrate as nitrogen (mg/L)	min.	0.7	0.3	0.4	0.4	0.5	0.3	0.2	0.2	10	1
	max.	1.3	0.9	1.3	1.2	0.9	1.4	0.7	2.3		
	avg.	0.9	0.6	0.8	0.7	0.8	0.7	0.5	0.9		

## Notes:

See Figure 5-6 for the locations of recharge basins.

(s) = stormwater

AGS/HFBR = Alternating Gradient Synchrotron/High Flux Beam Reactor

CSF = Central Steam Facility

Linac = Linear Accelerator

MDL = Minimum Detection Limit

NA = Not Applicable

NYSDEC = New York State Department of Environmental Conservation

RHIC = Relativistic Heavy Ion Collider

SNS = Effluent Standard Not Specified

SU = Standard Units

ping the particles before they reach groundwater. Lead was detected in a sample collected at Basin HZ in both the filtered and unfiltered samples. This was an isolated instance and could not be repeated in subsequent samples. Lead is present in native soils and is identified in soil sample analyses. Contamination of the water samples with very low levels of soil could be the cause of this finding.

Lead at the CSF outfall continued to be evaluated in 2005. In 2005, the Laboratory cleaned out several upstream manholes that contained sediment found to have high concentrations of lead. During heavy rain events, these sediments were being washed downstream and were collecting on the surface of the geotextile. Cleaning out the manholes precluded future movement and deposits of lead-contaminated soils.

Table 5-6. Metals Analysis of Water Samples from BNL On-Site Recharge Basins.

Recharge Basin																		NYSDEC Effluent Limit or AWQS	Typical MDL
METAL	Total or Filtered No. of samples	HN (RHIC)		HO (AGS)		HS (stormwater)		HT-E (AGS)		HT-W (Linac)		HW (stormwater)		CSF (stormwater)		HZ (stormwater)			
		T	F	T	F	T	F	T	F	T	F	T	F	T	F	T	F		
Ag Silver (µg/L)	min.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	19.8	20	19.4	<2.0	<2.0	0.06	<2.0	<2.0	<2.0	<0.1	<2.0	
	max.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	
	avg.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	
Al Aluminum (µg/L)	min.	40.3	13.1	10.9	<50.0	26.7	9	19.8	20	19.4	13	217	31.3	214	29.1	10.2	27.1	27.1	
	max.	434	<50.0	508	<50.0	733	23.8	215	<50.0	67.1	<50.0	2580	54.2	3030	202	238	58.1	58.1	
	avg.	247.7	<50.0	106.6	<50.0	280.4	15.2	92.9	<50.0	43.1	<50.0	1352.5	41.3	2074.7	88	73.5	42.6	42.6	
As Arsenic (µg/L)	min.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	0.8	<5.0	<5.0	<5.0	1.6	3.4	3.4	
	max.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	24.5	22.1	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	6.6	9.2	9.2	
	avg.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	10.9	13.9	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	6.3	6.3	
Ba Barium (µg/L)	min.	21.7	21.3	19.4	19.7	15.6	18.8	23.6	21.8	24.3	22.1	5	3.6	4.7	3	16.7	36.5	36.5	
	max.	44.6	37.3	23.5	21.8	37.3	35.4	135	58.8	30.3	26.8	24.7	8.8	45	21.6	51	46.8	46.8	
	avg.	29.1	27.9	20.5	20.8	25.1	26.4	69.9	42.7	26.5	24.7	13.8	6.4	21.2	9.3	30.2	41.7	41.7	
Be Beryllium (µg/L)	min.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	0.1	<2.0	<2.0	<2.0	<2.0	
	max.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	
	avg.	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	
Cd Cadmium (µg/L)	min.	0.1	0.3	0.1	<2.0	0.1	<2.0	1.3	<2.0	0.2	1.7	0.3	0.2	0.1	0.3	0.1	0.7	0.7	
	max.	1.4	<2.0	<2.0	<2.0	<2.0	<2.0	3.8	3.8	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	2.4	1.5	1.5	
	avg.	0.6	<2.0	<2.0	<2.0	<2.0	<2.0	2	2.2	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	1.1	1.1	
Co Cobalt (µg/L)	min.	0.3	1.7	0.5	1.1	0.43	1.4	1.1	1.8	0.2	3	1.5	0.7	1.4	1.9	0.5	2.5	2.5	
	max.	<5.0	2.5	<5.0	2.3	<5.0	4.9	<5.0	2.8	<5.0	5.3	<5.0	1.9	7.5	4.7	<5.0	<5.0	<5.0	
	avg.	<5.0	2.2	<5.0	1.7	<5.0	2.8	<5.0	2.2	<5.0	<5.0	<5.0	1.3	<5.0	2.9	<5.0	<5.0	<5.0	

(continued on next page)



Table 5-6. Metals Analysis of Water Samples from BNL On-Site Recharge Basins.

Recharge Basin																			
METAL	Total or Filtered No. of samples	HN (RHIC)		HO (AGS)		HS (stormwater)		HT-E (AGS)		HT-W (Linac)		HW (stormwater)		CSF (stormwater)		HZ (stormwater)		NYSDEC Effluent Limit or AWQS	Typical MDL
		T	F	T	F	T	F	T	F	T	F	T	F	T	F	T	F		
Cr Chromium (µg/L)	min.	5	<5.0	4.1	4	<5.0	<5.0	4.5	<5.0	4.4	<5.0	3.9	<5.0	<5.0	<5.0	2.9	3.9	100	1.0
	max.	7.2	7.3	8.2	<5.0	6.4	6.1	8.2	8.7	6.7	6	12.1	<5.0	8.2	<5.0	7.1	<5.0		
	avg.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	6.4	<5.0	<5.0	<5.0	<5.0	<5.0		
Cu Copper (µg/L)	min.	13	9.4	1.4	2.4	2.7	1.6	5.8	3.5	47.5	43.6	3.9	2.2	4.4	3	16.9	68.2	1000	2.0
	max.	54.9	33.8	8.8	5.9	9.2	8.4	86.7	62.5	307	260	28	13	28.6	12.1	133	108		
	avg.	27.3	17.9	5	4.2	6.4	4.3	45.5	37.4	127.1	131.2	13.2	6.3	16	6.1	56.6	88.1		
Fe Iron (mg/L)	min.	0.12	0.06	0.03	0.03	0.07	0.02	0.14	0.06	0.04	0.01	0.27	0.03	0.39	0.04	0.09	0.1	0.6	0.015
	max.	0.92	0.13	0.82	0.04	0.99	0.07	1.22	0.74	0.14	0.09	3.89	0.09	4.64	0.14	1.17	0.33		
	avg.	0.53	0.1	0.22	0.04	0.4	0.05	0.68	0.43	0.09	0.04	2.01	0.06	2.71	0.09	0.4	0.22		
Hg Mercury (µg/L)	min.	0.1	0.1	0.1	<0.2	<0.2	0.1	0.1	0.1	0.1	<0.2	0.1	0.1	<0.2	0.1	0.1	0.1	1.4	0.2
	max.	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2		
	avg.	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2		
Mn Manganese (µg/L)	min.	5	6.1	4.4	3.7	6.3	3.7	16.2	7.8	5	2.5	5	4.1	13.3	7	5.7	14.7	600	2.0
	max.	27.2	10.5	23.3	4.3	22.7	14.2	120	51.3	21.1	26.3	54.1	20.5	91.8	41	48.6	25.4		
	avg.	19.6	8.27	11.1	4	12.1	8.5	79.3	36.5	11.4	11.9	29.8	11.2	48.1	18.8	23.5	20.1		
Na Sodium (mg/L)	min.	19.6	20.3	18.6	18.6	19.1	19.5	23	22.5	21.6	22.2	1.62	1.61	4.38	4.09	20.5	47.4	SNS	1.0
	max.	51.8	51.7	32.8	32.4	32.9	30.7	1490	167	30.5	27.6	19.1	5.35	5.48	5.43	122	47.7		
	avg.	31.3	32.3	22.5	25.5	28.6	26.9	452.8	108.2	25.9	25.5	7.8	3.9	5	4.8	52	47.6		
Ni Nickel (µg/L)	min.	2.5	1.7	2	1.5	1.4	1.4	3.5	1.5	1.7	1.4	1.6	1.4	5.1	3.7	1.6	3.2	200	1.1
	max.	<10.0	3.8	<10.0	<10.0	2.6	2.6	10.3	4	<10.0	2.7	12.9	5.1	96.5	62.1	<10.0	5.1		
	avg.	<10.0	2.6	<10.0	<10.0	2	2.1	<10.0	3	<10.0	2.1	5.7	3.2	36	23.5	<10.0	4.2		

(continued on next page)

Table 5-6. Metals Analysis of Water Samples from BNL On-Site Recharge Basins (concluded).

Recharge Basin																			
METAL	Total or Filtered No. of samples	HN (RHIC)		HO (AGS)		HS (stormwater)		HT-E (AGS)		HT-W (Linac)		HW (stormwater)		CSF (stormwater)		HZ (stormwater)		NYSDEC Effluent Limit or AWQS	Typical MDL
		T	F	T	F	T	F	T	F	T	F	T	F	T	F	T	F		
Pb Lead (µg/L)	min.	0.8	<3.0	3	<3.0	0.6	0.7	1.8	1.7	<3.0	<3.0	2.7	0.9	2.3	1.5	0.7	6.7	50	1.3
	max.	2.9	<3.0	3	<3.0	5	<3.0	3.4	<3.0	<3.0	<3.0	26.8	<3.0	30.3	<3.0	73	58.2		
	avg.	2.3	<3.0	<3.0	<3.0	2.2	<3.0	<3.0	<3.0	<3.0	<3.0	14.4	<3.0	12.8	<3.0	18.4	32.5		
Sb Antimony (µg/L)	min.	0.9	0.7	0.8	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	0.8	0.7	0.7	1.3	<5.0	<5.0	6	0.9
	max.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	5.9	2	<5.0	<5.0	<5.0	<5.0		
	avg.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	1.2	<5.0	<5.0	<5.0	<5.0		
Se Selenium (µg/L)	min.	0.8	0.6	<5.0	<5.0	0.7	0.6	1.4	2	0.7	0.8	<5.0	1.1	0.7	<5.0	1.3	3.3	20	5
	max.	<5.0	0.8	<5.0	<5.0	<5.0	<5.0	17.7	14.7	<5.0	<5.0	<5.0	<5.0	1.3	<5.0	5.8	5.1		
	avg.	<5.0	0.7	<5.0	<5.0	<5.0	<5.0	5.9	5.6	<5.0	<5.0	<5.0	<5.0	0.9	<5.0	<5.0	4.2		
Tl Thallium (µg/L)	min.	<5.0	0.5	0.5	0.4	0.2	0.3	0.4	1.2	0.4	0.58	0.3	0.3	0.6	0.5	0.5	0.3	SNS	0.7
	max.	<5.0	1	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	1.8	<5.0	<5.0	<5.0		
	avg.	<5.0	0.8	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	1.3	<5.0	<5.0	<5.0		
V Vanadium (µg/L)	min.	4.2	<5.0	3.4	<5.0	<5.0	<5.0	<5.0	<5.0	4.7	2.9	<5.0	4.7	5.9	3.2	2	<5.0	SNS	5.5
	max.	<5.0	<5.0	<5.0	5.4	5.1	7.2	7.5	6.3	<5.0	<5.0	14.4	<5.0	63.2	30.9	<5.0	6.3		
	avg.	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	6.1	<5.0	26.3	12.8	<5.0	<5.0		
Zn Zinc (µg/L)	min.	23.4	20.3	1.2	2.7	5.7	6.3	8.5	7.1	6.9	5.7	20.2	18.8	21.8	13	26.1	49.2	5000	4
	max.	75.7	47.2	46.4	5.1	63	7.8	61.5	45.5	198	246	150	46.4	293	133	142	108		
	avg.	59	37	12.6	3.9	24.6	7.3	45.5	28.6	61.1	88.6	69.9	29.4	115.4	54.2	73.9	78.6		

## Notes:

See Figure 5-7 for the locations of recharge basins.

CSF = Central Steam Facility

NYSDEC = New York State Department of Environmental Conservation

AGS = Alternating Gradient Synchrotron

Linac = Linear Accelerator

RHIC = Relativistic Heavy Ion Collider

AWQS = Ambient Water Quality Standards

MDL = Minimum Detection Limit

SNS = Effluent Standard Not Specified

### 5.4.3 Stormwater Assessment

All recharge basins receive stormwater runoff. Stormwater at BNL is managed by collecting runoff from paved surfaces, roofs, and other impermeable surfaces and directing it to recharge basins via underground piping and abovegrade vegetated swales. Recharge Basin HS receives most of the stormwater runoff from the central, developed portion of the Laboratory site. Basins HN, HZ, HT-W, and HT-E receive runoff from the Collider-Accelerator complex. Basin HO receives runoff from the Brookhaven Graphite Research Reactor (BGRR) and HFBR areas. Basin CSF receives runoff from the Central Steam Facility area and along Cornell Avenue east of Railroad Avenue. Basin HW receives runoff from the warehouse area, and HW-M receives runoff from the fenced area at the former HWMF.

Stormwater runoff at the Laboratory typically has elevated levels of inorganics and low pH. The inorganics are attributable to high sediment content and the natural occurrence of these elements in native soil. In an effort to further protect the quality of stormwater runoff, BNL has finalized formal procedures for managing and maintaining outdoor work and storage areas. The requirements include covering areas to prevent contact with stormwater, conducting an aggressive maintenance and inspection program, and restoring these areas when operations cease.

## 5.5 PECONIC RIVER SURVEILLANCE

Several locations are monitored along the Peconic River to assess the overall water quality of the river and assess any impact from BNL discharges. Sampling points along the Peconic River are identified in Figure 5-8. In total, 10 stations (three upstream and seven downstream of the STP) were regularly sampled in 2005. A sampling station along the Carmans River (HH) was also monitored as a geographic control location, not affected by Laboratory operations. All locations were routinely monitored for radiological and nonradiological parameters. The sampling stations are located as follows:

### *Upstream sampling stations*

- HY, on site immediately east of the William Floyd Parkway

- HV, on site just east of the 10:00 o'clock Experimental Hall in the RHIC Ring
- HE, on site approximately 20 ft upstream of the STP outfall (EA)

### *Downstream sampling stations*

- HM-N, on site 0.5 mile downstream of the STP outfall
- HM-S, on site on a typically dry tributary of the Peconic River
- HQ, on site 1.2 miles downstream of the STP outfall at the site boundary
- HA, first station downstream of the BNL boundary, 3.1 miles from the STP outfall
- Donahue's Pond, off site, 4.3 miles downstream of the STP outfall. (Note: In 2005, some samples were collected at former station HC, due to access problems at Donahue's Pond. The two sites are very near one another, one within the pond and the other at the outflow from the pond.)
- Forge Pond, off site
- Swan Pond, off site not within the influence of BNL discharges

### *Control location*

- HH, Carmans River

### 5.5.1 Peconic River—Radiological Analyses

Radionuclide measurements were performed on surface water samples collected from the Peconic River at all 10 locations. Routine samples at Stations HM-N and HQ were collected once per month; all other stations were sampled quarterly unless conditions (such as no water flow) prevented collection. Stations HE, HM-N, and HQ have been equipped with Parshall flumes that allow automated flow-proportional sampling and volume measurements. All other sites were sampled by collecting instantaneous grab samples, as flow allowed.

The radiological data from Peconic River surface water sampling in 2005 are summarized in Table 5-7. Radiological analysis of upstream water samples showed that gross alpha and beta activity was detected at most Peconic River and Carmans River locations. The highest concentrations of gross beta activity were detected at Station HA, located downstream and off the Laboratory site. The average concentrations




Figure 5-8. Sampling Stations for Surface Water, Fish, and Shellfish.

from off-site and control locations were indistinguishable from BNL on-site levels. The beta activity for all locations is therefore attributed to natural sources. Samples collected downstream of the STP discharge showed concentrations typical of STP releases and historical values. All detected levels were below the applicable DWS. Swan Pond, a station along a Peconic River tributary but uninfluenced by BNL discharges, had the highest detection of gross alpha activity,  $4.2 \pm 1.5$  pCi/L. Again, the average alpha concentrations between upstream, downstream, and background locations were indistinguishable. No gamma-emitting radionuclides attributable to Laboratory operations were detected either upstream or downstream of the STP.

Tritium results for water samples collected upstream and downstream of the STP discharge were below detectable levels at all stations, except for a single detection of  $290 \pm 180$  pCi/L at station HM-N, downstream of the STP discharge. The New York State DWS for tritium is 20,000 pCi/L.

Monitoring for Sr-90 was performed at nine of the 10 stations sampled in 2005. Low-level detections were found at Stations HE, HM-N, and HM-S, at very consistent levels of 0.9, 0.6, and 0.5 pCi/L. These concentrations are consistent with historical levels and are attributed to worldwide fallout.

### 5.5.2 Peconic River–Nonradiological Analyses

Peconic River samples collected in 2005 were analyzed for water quality parameters (pH, temperature, conductivity, and dissolved oxygen), anions (chlorides, sulfates, and nitrates), metals, and VOCs. No VOCs above the MDL were detected in river water samples. The inorganic analytical data for the Peconic River and Carmans River samples are summarized in Tables 5-8 (water quality) and 5-9 (metals).

Peconic River water quality data collected upstream and downstream showed that water quality was consistent throughout the river system. These data were also consistent with those from the Carmans River control location (HH). Sulfates, chlorides, and nitrates tend to be slightly higher in samples collected imme-

Table 5-7. Radiological Results for Surface Water Samples Collected along the Peconic and Carmans Rivers.

		Gross Alpha	Gross Beta	Tritium	Sr-90
Sampling Station		(pCi/L)			
PECONIC RIVER					
HY	N	4	4	4	4
(headwaters) on site,	max.	< 1.2	3.6 ± 1.3	< 260	< 1.6
west of the RHIC ring	avg.	0.8 ± 0.4	2.6 ± 1.3	-4.5 ± 59.1	0.2 ± 0.1
HV	N	4	4	5	NS
(headwaters) on site,	max.	1.71 ± 0.87	8.8 ± 1.7	< 260	
inside the RHIC ring	avg.	1.0 ± 0.5	4.8 ± 3.1	-63.4 ± 72	
HE	N	4	4	4	3
upstream of	max.	1.7 ± 1.1	2.6 ± 1	< 260	0.9 ± 0.4
STP outfall	avg.	1 ± 0.5	1.9 ± 0.8	42.5 ± 104.8	0.5 ± 0.4
HM-N	N	12	12	12	6
downstream of STP,	max.	2.6 ± 1.2	6.6 ± 1.5	290 ± 180	0.6 ± 0.51
on site	avg.	0.6 ± 0.5	4.1 ± 0.9	71.8 ± 56.8	0.1 ± 0.4
HM-S	N	3	3	3	3
tributary, on site	max.	< 1.2	3 ± 1.2	< 270	0.5 ± 0.3
	avg.	0.4 ± 0.2	2.4 ± 0.7	-96.7 ± 169.9	0.3 ± 0.3
HQ	N	9	9	9	4
downstream of STP,	max.	< 1.2	5.6 ± 1.1	< 340	< 0.77
at BNL site boundary	avg.	0.01 ± 0.3	3.7 ± 0.8	88.9 ± 68.1	0.3 ± 0.1
HA	N	4	4	4	4
off site	max.	< 1.2	36.8 ± 4.3	< 230	< 0.54
	avg.	0.2 ± 0.5	10 ± 17.5	-60 ± 109.4	0.2 ± 0.1
HC	N	2	2	2	2
off site	max.	< 1	3.3 ± 0.99	< 220	< 0.54
	avg.	0.4 ± 0.6	2.4 ± 1.9	-80 ± 39.2	0.2 ± 0.1
Donahue's	N	2	2	2	2
Pond	max.	< 1.2	< 2.2	< 310	< 0.67
off site	avg.	0.7 ± 0.2	1.8 ± 0.5	-60 ± 58.8	0.2 ± 0.2
Forge Pond	N	4	4	4	4
off site	max.	< 0.95	13.6 ± 2.1	< 230	< 0.50
	avg.	0.3 ± 0.5	4.7 ± 5.8	-27.5 ± 108.7	0.2 ± 0.2
Swan Pond	N	4	4	4	4
control location,	max.	4.2 ± 1.5	6.4 ± 1.4	< 390	< 0.69
off site	avg.	1.6 ± 1.7	4.9 ± 1.6	25 ± 99.5	0.2 ± 0.3
HH Carmans River	N	4	4	4	4
control location,	max.	< 1.4	3.6 ± 1	< 390	< 0.62
off site	avg.	0.4 ± 0.2	1.9 ± 1.2	-12.5 ± 35.2	0.1 ± 0.2
SDWA Limit (pCi/L)		15	(a)	20,000	8

Notes:

See Figure 5-8 for locations of sampling stations.

All values reported with a 95% confidence interval.

Negative numbers occur when the measured values are lower than background (see Appendix B).

To convert values from pCi to Bq, divide by 27.03.

N = Number of samples analyzed

NS = Not Sampled for this analyte

SDWA = Safe Drinking Water Act

(a) The drinking water standard was changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in late 2003. Because gross beta activity does not identify specific radionuclides, a dose equivalent cannot be calculated for the values in the table.



## CHAPTER 5: WATER QUALITY

Table 5-8. Water Quality Data for Surface Water Samples Collected along the Peconic and Carmans Rivers.

ANALYTE		Recharge Basin											NYSDEC Effluent Standard	Typical MDL
		HY	HE	HM-N	HM-S	HQ	HA	HC	Donahue's Pond	Forge Pond	Swan Pond	HH		
No. of samples		4	4	12	3	9	4	2	2	4	4	4		
pH (SU)	min	4.2	5.0	5.2	4.0	5.2	6.0	6.0	6.2	6.6	5.9	6.4	6.5 – 8.5	NA
	max.	7.3	6.5	7.0	4.0	9.6	6.6	6.5	6.4	6.4	7.0	7.1		
Conductivity (µS/cm)	min.	78.0	50.0	153.0	67.0	55.0	58.0	64.0	74.0	101.0	69.0	158.0	SNS	NA
	max.	225.0	130.0	660.0	117.0	293.0	74.0	79.0	79.0	148.0	105.0	174.0		
	avg.	137.2	86.0	271.1	88.0	185.7	66.8	71.5	76.5	119.0	92.5	167.8		
Temperature (°C)	min.	1.1	4.2	0.6	0.0	2.2	1.3	12.3	1.7	3.5	1.8	5.8	SNS	NA
	max.	14.9	8.6	26.2	16.5	25.2	22.1	13.9	21.5	27.4	22.2	19.0		
	avg.	10.2	7.0	13.0	9.7	11.2	10.9	13.1	11.6	14.7	12.0	10.9		
Dissolved oxygen (mg/L)	min.	7.7	8.3	4.9	5.0	4.7	4.5	9.5	4.0	7.8	4.2	7.0	>4.0	NA
	max.	10.8	13.0	13.6	11.8	15.1	10.5	10.4	8.5	11.1	10.0	11.6		
	avg.	9.1	11.2	9.8	7.9	10.7	8.0	10.0	6.2	9.8	7.7	9.9		
Chlorides (mg/L)	min.	6.3	5.8	6.8	0.9	5.1	6.7	9.3	10.4	14.1	8.8	25.7	250(b)	4.0
	max.	33.5	11.6	68.7	5.4	48.3	9.3	11.2	12.2	24.6	15.7	29.7		
	avg.	17.0	8.2	39.1	3.7	27.8	8.4	10.3	11.3	17.8	11.2	27.6		
Sulfates (mg/L)	min.	0.4	3.7	7.9	0.3	6.3	3.2	5.2	3.3	8.0	2.8	11.0	250(b)	4.0
	max.	4.2	36.1	22.0	17.8	23.6	6.5	9.8	7.1	13.0	10.8	11.4		
	avg.	2.2	12.7	14.3	7.6	13.5	4.9	7.5	5.2	11.2	8.2	11.2		
Nitrate as nitrogen (mg/L)	min.	<0.02	<0.02	0.8	<0.02	<0.02	0.1	<0.02	<0.02	<0.02	<0.02	1.3	10(b)	1.0
	max.	1.0	0.7	7.8	1.3	4.1	1.0	1.0	0.1	0.8	0.8	2.4		
	avg.	0.4	0.3	4.1	0.6	1.4	0.2	0.5	0.1	0.3	0.2	1.6		

**Notes:**

- (a) See Figure 5-6 for the locations of recharge basins. Verbal descriptions are provided below.  
 (b) Since there are no NYSDEC Class C Surface Ambient Water Quality Standards (AWQS) for these compounds, the AWQS for groundwater is provided, if specified.

Donahue's Pond = Peconic River, off site  
 Forge Pond = Peconic River, off Site  
 HA = Peconic River, off site  
 HC = Peconic River, off site  
 HE = Peconic River, upstream of STP Outfall  
 HH = Carmans River control location, off site

HM-N = Peconic River on site, downstream of STP  
 HM-S = Peconic River tributary, on site  
 HQ = Peconic River, downstream of STP at BNL site boundary  
 HY = Peconic River headwaters, on site, east of Wm Floyd Pkwy.  
 MDL = Minimum Detection Limit  
 NA = Not Applicable  
 NYSDEC = New York State Department of Environmental Conservation  
 SNS = Effluent Standard Not Specified



Table 5-9. Metals Analysis in Surface Water Samples Collected along the Peconic and Carmans Rivers.

METAL	Peconic River Locations																				Control HH	NYSDEC AWQS	Typical MDL		
	HY		HE		HM-N		HM-S		HQ		HA		HC		D. P.		Swan Pond		Forge Pond						
	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D					
Total or Dissolved	4	2	5	1	13	6	3	1	9	5	4	2	2	2	2	2	4	2	4	2	4	2	2		
Ag (I)		<2.0	<2.0	<2.0	1.4	0.53	<2.0	<2.0	<2.0	<2.0	0.1	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		
Silver (µg/L)		<2.0	<2.0	*	18.4	<2.0	<2.0	*	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	2	
avg.		<2.0	<2.0	*	3.2	<2.0	<2.0	*	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		
Al (I)		552	282	165	186	19	558	855	119	87.1	103	109	76.5	67.7	48.7	34.6	28.6	24.5	44.1	43.7	19.3				
Aluminum (µg/L)		1040	668	857	*	2890	942	*	469	361	218	188	122	110	51.8	579	61.6	125	80.2	195	21.1		100	50	
avg.		726.5	475	494	*	603.4	89.9	792	*	285	197	146.3	148.5	99.3	88.9	239.9	45.1	66.35	62.15	103	20.2				
As (D)		<5.0	<5.0	3	<5.0	2.8	<5.0	<5.0	<5.0	<5.0	2.9	<5.0	<5.0	<5.0	2.1	3.2	<5.0	2.1	<5.0	<5.0	<5.0	<5.0		5	
Arsenic (µg/L)		<5.0	<5.0	*	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	150		
avg.		<5.0	<5.0	<5.0	*	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0			
Ba		7.7	8.7	11.1	<9.7	12.8	10.4	12.4	15.4	5.1	2.8	7.8	8.1	10.6	9.4	10.1	10.3	9.8	15.4	14.1	23.3	20.5			1.8
Barium (µg/L)		14.3	12.8	45.9	*	67.1	20.9	24.1	*	15.4	12.7	12.7	11	14.6	13.9	16.2	25.5	11.2	23.7	17.4	35.4	33.2		SNS	
avg.		11.8	10.8	20.9	*	26.2	14.7	17.5	*	10	8.3	10.4	9.6	12.6	11.7	13.15	14.48	10.5	18.9	15.8	31	26.85			
Be (AS)		<2.0	<2.0	0.2	<2.0	0.2	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0		2	
Beryllium (µg/L)		<2.0	<2.0	<2.0	*	<2.0	<2.0	<2.0	*	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
avg.		<2.0	<2.0	<2.0	*	<2.0	<2.0	<2.0	*	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Cd (D)		0.1	0.1	0.1	<2.0	0.1	0.1	0.1	0.1	0.11	0.1	0.1	0.1	<2.0	<2.0	<2.0	0.08	<2.0	<2.0	<2.0	<2.0	<2.0		2	
Cadmium (µg/L)		<2.0	<2.0	<2.0	*	1	0.26	<2.0	*	0.3	0.22	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
avg.		<2.0	<2.0	<2.0	*	0.4	0.2	<2.0	*	0.2	0.16	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0			
Co (AS)		0.5	2.5	0.5	3.4	0.6	0.8	0.4	1.7	<5.0	<5.0	0.1	1.8	<5.0	1.8	0.2	0.3	2.3	0.27	0.76	0.18	1.7			5
Cobalt (µg/L)		<5.0	4.5	4.3	*	<5.0	3.2	<5.0	*	<5.0	<5.0	<5.0	2	<5.0	2.5	<5.0	<5.0	2.7	<5.0	3.2	<5.0	2.1		5	
avg.		<5.0	3.5	1.8	*	<5.0	1.8	<5.0	*	<5.0	<5.0	<5.0	1.9	<5.0	2.2	<5.0	<5.0	2.5	<5.0	1.98	<5.0	1.9			

(continued on next page)

Table 5-9. Metals Analysis in Surface Water Samples Collected along the Peconic and Carmans Rivers (continued).

METAL	Peconic River Locations																				Control HH	NYSDEC AWQS	Typical MDL
	HY		HE		HM-N		HM-S		HQ		HA		HC		D. P.	Swan Pond		Forge Pond					
	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D			
Total or Dissolved No. of samples	4	2	5	1	13	6	3	1	9	5	4	2	2	2	2	4	2	4	2	4	2		
	3.9	<5.0	<5.0	5.8	4.7	4.3	4.6	<5.0	3.8	4.4	3.9	3.8	<5.0	3.8	4	<5.0	<5.0	4	<5.0	4.2	<5.0		
	9.9	<5.0	5.3	*	21.8	6.4	<5.0	*	6.4	6	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0		
	5.2	<5.0	<5.0	*	5.3	<5.0	<5.0	*	5.1	5.2	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0		
Cu (D) Copper (µg/L)	1.7	1.7	1.1	0.95	16.1	9.7	1.1	2.2	7	6.7	0.8	1.9	0.87	1	<10.0	1.1	1	0.5	0.85	0.38	1.1		
	20.2	4.7	13.5	*	144	58.1	1.6	*	27	14.5	2.8	2.5	0.98	1.1	15.9	6.4	1.3	<10.0	1.2	<10.0	<10.0		
	7.2	3.2	4.4	*	44.3	22.7	1.3	*	13.1	9.7	1.7	2.2	0.92	1.1	<10.0	2.9	1.15	<10.0	1.02	<10.0	<10.0		
Fe (AS) Iron (mg/L)	0.4	0.4	0.3	0.64	0.3	0.1	0.2	0.7	0.3	0.1	0.5	0.6	0.9	0.65	0.69	0.11	0.07	0.64	0.5	0.36	0.19		
	0.8	0.5	5.9	*	2.4	0.4	0.7	*	0.5	0.3	3.02	0.7	0.96	0.66	2.66	0.8	0.12	1.1	0.83	0.58	0.24		
	0.6	0.5	3.2	*	0.9	0.2	0.5	*	0.4	0.2	1.27	0.6	0.93	0.66	1.67	0.4	0.1	0.84	0.67	0.45	0.21		
Hg (D) Mercury (µg/L)	0.1	0.1	<0.2	55.3	0.1	0.1	<0.2	<0.2	<0.2	<0.2	0.01	0.1	<0.2	0.06	<0.2	0.1	0.06	0.07	0.08	0.06	0.06		
	<0.2	<0.2	<0.2	*	1.2	<0.2	<0.2	*	0.3	<0.2	<2.0	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2		
	avg.	<0.2	<0.2	*	<0.2	<0.2	<0.2	*	<0.2	<0.2	<2.0	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	0.21		
Mn Manganese (µg/L)	9.2	32.7	55.8	55.3	13.3	13.9	34.4	37.3	9.9	2.2	17.7	20.5	30.3	30.4	66.8	48.6	32.2	58.8	73.1	57.1	0.06		
	56.1	40.7	265	*	80.7	77.3	52.1	*	77.2	69.1	81.9	59.6	219	215	247	546	88.9	161	147	90.8	<0.2		
	33.9	36.7	174.4	*	45.1	31.8	40.8	*	32.9	25.1	49.1	40.1	124.7	122.7	156.9	275.9	60.6	112.7	110.1	68	<0.2		
Na Sodium (mg/L)	8.8	9.3	5.1	5.3	5.4	5.5	3.1	3.29	3.89	3.9	5.2	6.18	7.1	6.95	7.89	6.4	6.49	9.63	9.49	17	60.2		
	33.8	34.7	8.8	*	54	54	3.3	*	39.3	35.4	7.5	7.51	7.2	7.1	8.12	9.9	7.09	14.7	10.2	19.3	60.8		
	20.8	22	6.2	*	29.9	31.2	3.2	*	24.3	23.86	6.3	6.84	7.1	7.02	8.01	7.5	6.79	12.01	9.85	18.15	60.5		
Ni (D) Nickel (µg/L)	1.4	1.5	1.3	1.7	6.5	4.5	1.2	1.7	<10.0	<10.0	0.6	1.5	<10.0	1.3	0.51	1.5	1.3	0.59	1.2	0.55	17.1		
	<10.0	2.4	<10.0	*	28.9	20.9	1.8	*	13	<10.0	<10.0	1.9	<10.0	1.7	10	<10.0	1.4	<10.0	1.3	<10.0	18.4		
	avg.	<10.0	2	<10.0	*	14	10.7	1.47	<10.0	<10.0	<10.0	1.7	<10.0	1.5	<10.0	<10.0	1.35	<10.0	1.3	<10.0	17.6		

(continued on next page)

Table 5-9. Metals Analysis in Surface Water Samples Collected along the Peconic and Carmans Rivers (concluded).

METAL		Peconic River Locations																				Control HH	NYSDEC AWQS	Typical MDL
		HY		HE		HM-N		HM-S		HQ		HA		HC		D. P.		Swan Pond		Forge Pond				
T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	T	D	
Total or Dissolved	4	2		5	1	13	6	3	1	9	5	4	2	2	2	2	4	2	4	2	4	2	2	
Pb (D)	2.4	2.4	1.3	<3.0	0.7	1.2	1.1	1.2	<3.0	<3.0	<3.0	1	0.6	0.65	0.62	1.1	1.2	0.81	0.58	<3.0	0.58	1.2	1.2	
Lead	4.3	2.5	<3.0	*	15.7	<3.0	<3.0	<3.0	*	<3.0	<3.0	<3.0	<3.0	1.1	0.98	0.71	<3.0	<3.0	<3.0	<3.0	<3.0	1.7	1.7	
(µg/L)	3.4	2.5	<3.0	*	3.1	<3.0	<3.0	<3.0	*	<3.0	<3.0	<3.0	0.8	0.82	0.66	<3.0	4.45	<3.0	<3.0	<3.0	<3.0	1.5	3	
Sb	1.1	0.8	<5.0	<5.0	0.9	1.9	<5.0	<5.0	<5.0	<5.0	0.8	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0		
Antimony	<5.0	1	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0	5	
(µg/L)	<5.0	0.8	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0		
Se (D)	0.7	0.8	0.7	<5.0	0.64	0.8	0.8	<5.0	<5.0	<5.0	<5.0	1	0.8	<5.0	<5.0	<5.0	0.81	<5.0	0.57	0.88	0.76	0.73		
Selenium	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0	5	
(µg/L)	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0		
Tl (AS)	0.6	0.7	0.3	<5.0	0.23	<5.0	<5.0	0.31	<5.0	<5.0	<5.0	0.5	0.5	<5.0	<5.0	<5.0	0.26	0.64	0.38	<5.0	<5.0	0.73		
Thallium	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	1.3	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	5	
(µg/L)	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	<5.0	*	<5.0	<5.0	0.8	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0		
V (AS)	<5.0	<5.0	4.8	<5.0	1.7	1.9	1.6	<5.0	<5.0	<5.0	<5.0	1.8	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	0.28		
Vanadium	<5.0	<5.0	7.3	*	13.7	8.3	2.4	*	<5.0	<5.0	<5.0	7	<5.0	<5.0	<5.0	6.2	<12.5	<5.0	5.4	<5.0	5.8	<5.0	5	
(µg/L)	<5.0	<5.0	<5.0	*	<5.0	<5.0	<5.0	1.9	*	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<12.5	<5.0	<5.0	<5.0	<5.0	<5.0		
Zn (D)	15.4	16	6	14.1	25	19.7	17.1	36.6	12.5	14.2	4.1	6.9	1.8	7.8	6.1	3.8	5.7	2.7	4.7	2.3	6.9			
Zinc	49.7	42.9	117	*	177	79	32.9	*	65.4	33.6	11.6	12.6	8.5	13.1	<10.0	24.3	7.8	<10.0	14.6	<10.0	6.9			
(µg/L)	27.4	29.5	38.9	*	70.4	38	25.87	*	29.3	24.5	7.6	9.8	5.2	10.5	<10.0	10.15	6.8	<10.0	9.65	<10.0	6.9	10		

Notes:

See Figure 5-8 for the locations of sample stations.

\*Only one sample taken; no min/max, no average

AWQS = Ambient Water Quality Standards

AS = Acid Soluble

D = Dissolved

D. P. = Donahue's Pond

I = Ionic

MDL = Minimum Detection Limit

NYSDEC = New York State Department of Environmental Conservation

RHIC = Relativistic Heavy Ion Collider

SNS = Effluent Standard Not Specified for these elements in Class C Surface Waters

diately downstream of the STP discharge (Stations HM-N and HQ) and were consistent with the concentrations in the STP discharge. All nitrate levels were less than 10 mg/L. There are no AWQS imposed for chloride or sulfates in discharges to surface water; however, NYSDEC imposes a limit of 500 mg/L for discharges to groundwater.

The pH measured at several locations was very low, due to the low pH of precipitation, groundwater, and the formation of humic acids from decaying organic matter. As spring rains mix with decaying matter, these acids decrease the already low pH of precipitation, resulting in a pH as low as 4.2 Standard Units. A discussion of precipitation monitoring is provided in Chapter 6 (see Section 6.7 for more detail).

Ambient water quality standards for metallic elements are based on their solubility state. Certain metals are only biologically available to aquatic organisms if they are in a dissolved or ionic state, whereas other metals are toxic in any form (i.e., dissolved and particulate combined). In 2005, the BNL monitoring program continued to assess water samples for both the dissolved and particulate form. Dissolved concentrations were determined by filtering the samples prior to acid preservation and analysis. Examination of the metals data showed that aluminum, copper, iron, lead, nickel, silver, and zinc were present in concentrations at some locations that exceeded AWQS both upstream and downstream of the STP discharge. Aluminum and iron are detected throughout the Peconic and Carmans Rivers at concentrations that exceed the NYS AWQS in both the filtered and unfiltered fractions. Both are found in high concentrations in native Long Island soil and, for iron, at high levels in groundwater. The low pH of groundwater and precipitation contribute to the dissolution of these elements. Although most metals were detected in upstream samples (indicating a natural presence), the highest levels for silver, copper, lead, nickel, and zinc were detected in samples collected immediately downstream of the Laboratory's STP discharge (HM-N). The concentrations detected were consistent with the concentrations found in the

STP discharge and, in most instances, were within the BNL SPDES permit limits. The NYS AWQS limits for copper, silver, and zinc are extremely restrictive (for silver and copper, less than the typical MDL); consequently, the NYS-granted SPDES permit allows higher limits provided toxicity testing shows no impact to aquatic organisms. Filtration of the samples reduced concentrations of most metals to below the NYS AWQS, indicating that most detections were due to sediment carryover.

Mercury was detected in single samples collected from Stations HM-N and HQ, both downstream of the Laboratory's STP discharge. Metals such as mercury can pose a risk for human consumption when they enter the food chain. In 2005, BNL completed an extensive project to remove contaminants from the Peconic River by excavating 6 to 12 inches of sediment from the river bottom. Remediation began immediately downstream of the STP discharge and continued off site into the County Parks east of the Laboratory's boundary. Once remediation was completed, monitoring of river water, sediment, vegetation, and fish samples was performed to determine the project's effectiveness. Mercury levels in the water initially rose, most likely due to disturbances of mercury deposits within the buried sediments. The mercury levels in the water are expected to drop as the sediments settle and are covered with fresh silt from stormwater runoff. The mercury levels in the sediments were lower than the pre-cleanup levels.

#### REFERENCES AND BIBLIOGRAPHY

- BNL. 1998. *Operable Unit V: Remedial Investigation and Risk Assessment of the Eastern Area of the Laboratory*. Brookhaven National Laboratory, Upton, NY.
- BNL. 2001. Standards Based Management System Subject Area: *Liquid Effluents*. Brookhaven National Laboratory, Upton, NY. May 2001.
- DOE Order 5400.5 1990. *Radiation Protection of the Public and the Environment*. U.S. Department of Energy, Washington, DC. Change 2: 1-7-93.
- NYCRR Part 703.6. Title 6. 1999. *Surface Water and Groundwater Quality Standards and Groundwater Effluent Limitations*. New York State Department of Environmental Conservation. Albany, NY. Change 8-4-99.