

Groundwater Protection

The Brookhaven National Laboratory Groundwater Protection Program is made up of four elements: prevention, monitoring, restoration, and communication. The Laboratory has implemented aggressive pollution prevention measures to protect groundwater resources. An extensive groundwater monitoring well network is used to verify that prevention and restoration activities are effective. In 2008, BNL collected groundwater samples from 860 monitoring wells during 2,170 individual sampling events. Twelve groundwater remediation systems removed 220 pounds of volatile organic compounds and returned approximately 1.5 billion gallons of treated water to the Upper Glacial aquifer. Since the beginning of active groundwater remediation in December 1996, the Laboratory has removed 6,117 pounds of volatile organic compounds by treating 14.4 billion gallons of groundwater. During 2008, two groundwater treatment systems removed approximately 3.4 millicuries of strontium-90 while remediating nearly 15 million gallons of groundwater. Since 2003, BNL has removed approximately 20.2 millicuries of strontium-90 from the groundwater while remediating 49.4 million gallons of groundwater.

7.1 THE BNL GROUNDWATER PROTECTION MANAGEMENT PROGRAM

The primary goal of BNL's Groundwater Protection Program is to ensure that plans for groundwater protection, management, monitoring, and restoration are fully defined, integrated, and managed in a manner that is consistent with federal, state, and local regulations. The program helps to fulfill the environmental monitoring requirements outlined in DOE Order 450.1, Environmental Protection Program. The program consists of four interconnecting elements: 1) preventing pollution of the groundwater, 2) monitoring the effectiveness of engineered and administrative controls at operating facilities and groundwater treatment systems, 3) restoring the environment by cleaning up contaminated soil and groundwater, and 4) communicating with stakeholders on groundwater protection issues. The Laboratory is committed to protecting groundwater resources from further chemical and radionuclide releases, and to remediating existing contaminated groundwater.

7.1.1 Prevention

As part of BNL's Environmental Management System, the Laboratory has implemented a number of pollution prevention activities that are designed to protect groundwater resources (see Chapter 2). BNL has established a work control program that requires the assessment of all experiments and industrial operations to determine their potential impact on the environment. The program enables the Laboratory to integrate pollution prevention and waste minimization, resource conservation, and compliance into planning and decision making. Efforts have been implemented to achieve or maintain compliance with regulatory requirements and to implement best management practices designed to protect groundwater (see Chapter 3). Examples include upgrading underground storage tanks, closing cesspools, adding engineered controls (e.g., barriers to prevent rainwater infiltration that could move contaminants out of the soil and into groundwater), and administrative controls (e.g., reducing the toxicity and volume of chemicals in use).

Table 7-1. Summary of BNL Groundwater Monitoring Program, 2008.

	CERCLA Program	Facility Monitoring Program
Number of wells monitored	735	125
Number of sampling events	1,901	269
Number of analyses performed	3,341	402
Number of results	71,442	4,647
Percent of nondetectable analyses	90	90
Number of permanent wells installed	21	0
Number of temporary wells installed	86	29
Number of wells abandoned	64	0

or storage). BNL's comprehensive groundwater monitoring program is used to confirm that these controls are working.

7.1.2 Monitoring

The Laboratory's groundwater monitoring network is designed to evaluate the impacts of groundwater contamination from former and current operations and to track cleanup progress. Each year, BNL collects groundwater samples from an extensive network of on- and off-site monitoring wells (see Table 7-1). Results from groundwater monitoring are used to verify that protection and restoration efforts are working. Groundwater monitoring is focused on two general areas: 1) Facility Monitoring (FM), designed to satisfy DOE and New York State monitoring requirements for active research and support facilities, and 2) Comprehensive Environmental Response, Compensation and Liability (CERCLA) monitoring related to the Laboratory's obligations under the Federal Facilities Agreement (FFA). These monitoring programs are coordinated to ensure completeness and to prevent duplication of effort in the installation, monitoring, and decommissioning of wells. The monitoring program elements include data quality objectives; plans and procedures; sampling and analysis; quality assurance; data management; and the installation, maintenance, and decommissioning of wells.

These elements are integrated to create a cost-effective monitoring system and to ensure that water quality data are available for review and interpretation in a timely manner.

7.1.3 Restoration

BNL was added to the National Priorities List in 1989. To help manage the restoration effort, 31 separate Areas of Concern were grouped into six Operable Units (OUs). Remedial Investigation/Feasibility Studies have been conducted for each OU, and the focus is currently on operating and maintaining cleanup systems. Contaminant sources (e.g., contaminated soil and underground storage tanks) are being removed or remediated to prevent further contamination of groundwater. All remediation work is carried out under the FFA involving EPA, the New York State Department of Environmental Conservation (NYSDEC), and DOE.

7.1.4 Communication

BNL's Community Education, Government and Public Affairs Office ensures that the Laboratory communicates with its stakeholders in a consistent, timely, and accurate manner. A number of communication mechanisms are in place, such as press releases, web pages, mailings, public meetings, briefings, and roundtable discussions. Specific examples include routine meetings with the Community Advisory Council and the Brookhaven Executive Roundtable (see Chapter 2, Section 2.4.2). Quarterly and annual technical reports that summarize data, evaluations, and program indices are prepared. In addition, BNL has developed a Groundwater Protection Contingency Plan (BNL 2008) that provides formal processes to promptly communicate off-normal or unusual monitoring results to Laboratory management, DOE, regulatory agencies, and other stakeholders, including the public and employees.

7.2 GROUNDWATER PROTECTION PERFORMANCE

BNL has made significant investments in environmental protection programs, and is making progress in achieving its goal of preventing new groundwater impacts and remediating previously contaminated groundwater.

No new impacts to groundwater quality have been identified since 2001. A new impact is defined as the detection and confirmation of previously unidentified groundwater contamination. The Groundwater Protection Contingency Plan, mentioned earlier as a communications tool, also is designed to ensure that appropriate and timely actions are taken if unusual or off-normal results are observed. The contingency plan provides guidelines for verifying the data, evaluating the source of the problem, notifying stakeholders, and implementing appropriate corrective actions. The Laboratory will continue efforts to prevent new groundwater impacts, and is vigilant in measuring and communicating its performance.

Since the start of active groundwater remediation in December 1996, BNL has made significant progress in restoring groundwater quality by removing over 6,100 pounds of volatile organic compounds (VOCs) and 20 millicuries (mCi) of strontium-90 (Sr-90) from the aquifer. Noticeable improvements in groundwater quality are evident in a number of on-site and off-site areas.

7.3 GROUNDWATER MONITORING

Elements of the groundwater monitoring program include installing monitoring wells; planning and scheduling; developing and following quality assurance procedures; collecting and analyzing samples; verifying, validating, and interpreting data; and reporting. Monitoring wells are used to evaluate BNL's progress in restoring groundwater quality, to comply with regulatory permit requirements, to monitor active research and support facilities, and to assess the quality of groundwater that enters and exits the site.

The Laboratory monitors research and support facilities where there is a potential for environmental impact, as well as areas where past waste handling practices or accidental spills have already degraded groundwater quality. The groundwater beneath the site is classified by New York State as Class GA groundwater, which is defined as a source of potable water. Federal drinking water standards (DWS), New York State DWS, and New York State Ambient Water Quality Standards (NYS AWQS) for Class GA groundwater are used as goals for


groundwater protection and remediation. BNL evaluates the potential impact of radiological and nonradiological contamination by comparing analytical results to the standards. Contaminant concentrations that are below the standards are also compared to background values to evaluate the potential effects of facility operations. The detection of low concentrations of facility-specific VOCs or radionuclides may provide important early indications of a contaminant release and allow for timely identification and remediation of the source.


Groundwater quality at BNL is routinely monitored through a network of approximately 860 on- and off-site wells (see SER Volume II, Groundwater Status Report, for details). In addition to water quality assessments, water levels are routinely measured in more than 875 on- and off-site wells to assess variations in the direction and velocity of groundwater flow. Groundwater flow directions in the vicinity of the Laboratory are shown in Figure 7-1.


The following active facilities have groundwater monitoring programs: the Sewage Treatment Plant (STP) area, Waste Management Facility (WMF), Major Petroleum Facility (MPF), Alternating Gradient Synchrotron (AGS), Relativistic Heavy Ion Collider (RHIC), and several vehicle maintenance and petroleum storage facilities. Inactive facilities include the former Hazardous Waste Management Facility (HWMF), two former landfill areas, Waste Concentration Facility (WCF), Brookhaven Graphite Research Reactor (BGRR), High Flux Beam Reactor (HFBR), and Brookhaven Medical Research Reactor (BMRR). As a result of detailed groundwater investigations, six significant VOC plumes and eight radionuclide plumes have been identified (see Figures 7-2 and 7-3).

7.4 SUPPLEMENTAL MONITORING OF WATER SUPPLY WELLS

Most of BNL's water supply is obtained from a network of six large-capacity wells (wells 4, 6, 7, 10, 11, and 12). A seventh well, number 9, is a small-capacity well that supplies process water to a facility where biological research is conducted. This well is in limited operation and is not routinely monitored. The locations of the







supply wells are shown in Figure 7-1. All of the Laboratory's supply wells are screened within the Upper Glacial aquifer.

As described in Chapter 3, the quality of the BNL potable water supply is monitored as required by the Safe Drinking Water Act (SDWA), and the analytical results are reported to the Suffolk County Department of Health Services (SCHDS). During 2008, the BNL potable water system fully complied with all drinking water requirements. The Laboratory conducts supplemental sampling of the water supply that goes beyond the minimum SDWA required testing. This additional testing is conducted because some of the potable supply wells are near known or suspected groundwater contamination plumes and source areas. This program includes additional testing for VOCs, anions, metals, strontium-90 (Sr-90) and tritium, which are known to have contaminated the groundwater in several areas of the site.

To better understand the geographical source of the Laboratory's drinking water and to identify potential sources of contamination within these geographical areas, BNL prepared a Source Water Assessment for Drinking Water Supply Wells (Bennett et al. 2000). In 2003, the New York State Department of Health (NYS-DOH) prepared a source water assessment for all potable water supply wells on Long Island, including the BNL potable supply wells (NYS-DOH 2003). The source water assessments are designed to serve as management tools in further protecting Long Island's sole source aquifer system.

7.4.1 Radiological Results

During 2008, samples collected from the six potable supply wells were analyzed for gross alpha and gross beta activity, tritium, and Sr-90 (see Table 7-2). Nuclide-specific gamma spectroscopy was also performed. All radioactivity levels in the potable water well samples were consistent with those of typical background water samples.

7.4.2 Nonradiological Results

In addition to the quarterly SDWA compliance samples described in Section 3.7 of Chapter 3,

Table 7-2. Potable Well Radiological Analytical Results.

Potable Well ID		Gross Alpha	Gross Beta	Tritium	Sr-90
		pCi/L			
Well 4	Samples	4	4	4	4
	Max.	< 1.88	< 2.18	< 310	< 0.71
	Avg.	0.51 ± 0.28	1.08 ± 0.83	64.62 ± 104.21	0.1 ± 0.2
Well 6	Samples	4	4	4	4
	Max.	< 1.86	< 2.25	< 310	< 0.76
	Avg.	0.58 ± 0.18	0.93 ± 0.76	30.17 ± 112.69	-0.02 ± 0.1
Well 7	Samples	4	4	4	4
	Max.	< 1.95	< 2.09	< 310	< 0.78
	Avg.	0.79 ± 0.54	0.79 ± 0.3	-17.1 ± 94.4	0.11 ± 0.47
Well 10	Samples	1	1	1	1
	Max.	< 1.96	< 2.62	< 257	< 0.5
	Avg.	N/A	N/A	N/A	N/A
Well 11	Samples	4	4	4	4
	Max.	1.95 ± 1.44	< 2.12	< 310	< 0.89
	Avg.	0.89 ± 0.75	1.48 ± 0.63	110.88 ± 57.65	0.12 ± 0.09
Well 12	Samples	3	3	3	3
	Max.	< 1.96	2.85 ± 0.85	< 320	< 0.73
	Avg.	0.02 ± 0.72	1.7 ± 1.17	63.97 ± 66.61	0.02 ± 0.34
SDWA Limit (pCi/L)		15 (a)	4 mrem (b)	20,000	8

Notes:

See Figure 7-1 for well locations.

All values presented with a 95% confidence interval.

Potable Well #10 has been shut down since 2000 due to its possible effect on groundwater flow direction in the vicinity of the g-2 Tritium Plume.

WS = Well shut down due to operational problems

(a) Excluding radon and uranium

(b) The drinking water standards were changed from 50 pCi/L concentration based to dose based in late 2003. Because gross beta activity does not identify specific radionuclides, a dose equivalent cannot be calculated for the values in the table. Corresponding gamma analyses verified that no nuclide exceeded the 4 mrem limit.

BNL collected supplemental VOC samples from active supply wells during the year. The samples were analyzed for VOCs following either EPA Standard Method 524 or 624. As in past years, low levels of several VOCs (e.g., chloroform, 1,1,1-trichloroethane [TCA], bromodichloromethane, and dibromochloromethane) were occasionally detected in the supply wells, but at concentrations well below the applicable drinking water standards. Samples were also analyzed for metals and anions one time during the year (see Tables 7-3 and 7-4). As in previous years, iron (Fe) was the only parameter detected

Table 7-3. Potable Water Supply Wells Water Quality Data.

Potable Well ID		Chlorides	Sulfates	Nitrate and Nitrite
		mg/L		
Well 4	N	1	1	1
	Value	26.4	8.7	0.22
Well 6	N	1	1	1
	Value	15.3	8.4	0.09
Well 7	N	1	1	1
	Value	24.4	10.1	0.23
Well 11	N	1	1	1
	Value	30.7	10.7	0.49
Well 12	N	1	1	1
	Value	24.3	12.9	0.46
NYS DWS		250	250	10
Typical MDL		4	4	1

Notes:

See Figure 7-1 for well locations.

Potable Well #10 has been shut down since 2000 due to its possible effect on groundwater flow direction in the vicinity of the g-2 Tritium Plume.

N = Number of samples

NYS DWS = New York State Drinking Water Standard

MDL = Minimum Detection Limit

at concentrations greater than the 0.3 mg/L DWS. The iron levels in wells 4, 6, and 7 were 1.3 mg/L, 2.9 mg/L, and 2.4 mg/L, respectively. Because high levels of iron are naturally present in some portions of the Upper Glacial aquifer on the western side of the Laboratory site, water obtained from wells 4, 6, and 7 is treated at the BNL Water Treatment Plant to reduce iron levels to below the 0.3 mg/L DWS before it is distributed.

7.5 FACILITY MONITORING PROGRAM

BNL's Facility Monitoring program includes groundwater monitoring at 10 active research facilities (e.g., accelerator beam stop and target areas) and support facilities (e.g., fuel storage and waste management facilities). During 2008, groundwater samples were collected from 125 wells during 269 individual sampling events. Detailed descriptions and maps related to the FM groundwater monitoring program can be found in SER Volume II, Groundwater Status Report.

Although no new impacts to groundwater quality have been discovered since 2001,

groundwater quality continues to be impacted at two BNL facilities: continued periodic high levels of tritium at the g-2 tritium source area, and continued high levels of VOCs at the Upton service station. Highlights of the surveillance program are as follows:

- Tritium continues to be detected in the g-2 source area monitoring well, at concentrations above the 20,000 pCi/L DWS. A short-term spike in tritium levels was observed in January 2008, with a tritium concentration of 186,000 pCi/L detected in the source area. Tritium levels in the source area wells dropped to less than 50,000 pCi/L by the fourth quarter of the year. Although the engineered stormwater controls are effectively protecting the activated soil shielding at the source area, monitoring data indicate that the continued release of tritium appears to be related to the flushing of residual tritium from the deep vadose zone following significant natural periodic fluctuations in the local water table.
- Monitoring of the downgradient areas of the g-2 tritium plume was accomplished using a combination of permanent and temporary wells. The highest tritium concentration in the downgradient segment of the plume was 80,700 pCi/L, observed immediately south of the HFBR. The southern extent of the plume was tracked to the Temple Place area, where a maximum tritium concentration of 33,300 pCi/L was detected. As a result of natural radioactive decay and dispersion in the aquifer, the tritium plume appears to be breaking up into discrete segments.
- Since April 2006, all tritium concentrations in the Brookhaven Linear Isotope Producer (BLIP) facility surveillance wells have been less than the 20,000 pCi/L DWS. The maximum tritium concentration during 2008 was 5,630 pCi/L. These results indicate that the engineered stormwater controls are effectively protecting the activated soil shielding, and that the amount of residual tritium in the deep vadose zone is diminishing.
- At the Service Station, VOCs associated with petroleum products and the solvent PCE continue to be detected in the ground-

water directly downgradient of the facility. Total VOC concentrations in one well reached a maximum of 1,575 µg/L; with the contamination consisting mostly of xylenes, ethylbenzene, and trimethylbenzenes. Groundwater monitoring results indicate that the petroleum-related compounds break down within a short distance from the facility. Monitoring of the leak detection systems at the Upton Service Station indicates that the gasoline storage tanks and associated distribution lines are not leaking, and all waste oils and used solvents are being properly stored and recycled. Therefore, it is believed that the contaminants detected in groundwater originate from historical vehicle maintenance activities and are not related to current operations.

7.6 CERCLA MONITORING PROGRAM

The CERCLA groundwater monitoring program is used to track the progress that the groundwater treatment systems are making toward plume remediation (see Section 7.7, below). During 2008, the CERCLA program monitored 735 monitoring wells during 1,901 individual groundwater sampling events.

Maps showing the main VOC and radionuclide plumes are provided as Figures 7-2 and 7-3, respectively. Detailed descriptions and maps related to the CERCLA groundwater monitoring program can be found in SER Volume II, Groundwater Status Report. Highlights of the program are described below.

- The HFBR Pump and Recharge system was operational during all of 2008. Monitoring data indicate that the elevated zone of tritium is approaching newly installed extraction well EW-16. The system is expected to remain operational for several years until this elevated concentration zone has been completely captured, and tritium concentrations in the area decrease below the 20,000 pCi/L Drinking Water Standard (DWS).
- Following a combined soil boring and soil gas characterization effort, the source of the Building 96 tetrachloroethylene (PCE) plume was identified and delineated during

Table 7-4. Total Metals Concentration Data for Potable Water Supply Well Samples.

Well ID	Ag µg/L	Al µg/L	As µg/L	Ba µg/L	Be µg/L	Cd µg/L	Co µg/L	Cr µg/L	Cu µg/L	Fe mg/L	Hg µg/L	Mn µg/L	Na mg/L	Ni µg/L	Pb µg/L	Sb µg/L	Se µg/L	Tl µg/L	V µg/L	Zn µg/L
Well 4 *	N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Value	< 2.0	< 50.0	< 5.0	< 2.0	< 2.0	< 5.0	< 5.0	5.3	1.28	< 0.2	230	17.8	< 10	< 3.0	< 5.0	< 5.0	< 5.0	1	8.3
Well 6 *	N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Value	< 2.0	< 50.0	19.1	< 2.0	< 2.0	< 5.0	< 5.0	11.6	2.91	< 0.2	173	10.1	27.9	< 3.0	< 5.0	< 5.0	< 5.0	3.3	9.2
Well 7 *	N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Value	< 2.0	< 50.0	22	< 2.0	< 2.0	< 5.0	< 5.0	16.9	2.35	< 0.2	70.3	17.1	< 10	< 3.0	< 5.0	< 5.0	< 5.0	2.5	7.7
Well 11	N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Value	< 2.0	< 50.0	31.5	< 2.0	< 2.0	< 5.0	< 5.0	7.4	0.03	< 0.2	< 5.0	20.3	< 10	< 3.0	< 5.0	< 5.0	< 5.0	1.4	4.4
Well 12	N	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Value	< 2.0	< 50	27.9	< 2.0	< 2.0	< 5.0	< 5.0	5.3	< 0.05	< 0.2	< 5.0	16.9	< 10	< 3.0	< 5.0	< 5.0	< 5.0	3	2.1
NYS DWS	100	SNS	50	2000	4	5	SNS	100	1300	0.3	2	300	SNS	SNS	15	6	50	2	SNS	5000
Typical MDL	2.0	50	5.0	20.0	2.0	2.0	5.0	5.0	10.0	0.05	0.2	5.0	0.3	10.0	3	5.0	5.0	5.0	5.0	10.0

Notes:

See Figure 7-1 for location of wells.

Potable Well #10 has been shut down since 2000 due to its possible effect on groundwater flow direction in the vicinity of the g-2 Tritium Plume.

* Water from these wells is treated at the Water Treatment Plant for color and iron reduction prior to site distribution.

MDL = Minimum Detection Limit

NYS DWS = New York State Drinking Water Standard

SNS = Drinking Water Standard not specified
NS = Well was not in operation during sample period

2008. Plans are being made to excavate a small area of contaminated soils south of the former Building 96, and dispose of the soils off site. The removal of this source area is expected to significantly reduce PCE levels in the groundwater within three to five years, and allow for the groundwater treatment system to be turned off. A temporary plastic cover was placed over the contaminated soils source area until excavation is undertaken. An Explanation of Significant Differences (ESD) documenting the source area excavation will be submitted to the regulatory agencies in April 2009.

- A joint groundwater characterization effort was undertaken to define the present locations of the co-located downgradient segments of the g-2 tritium plume and the WCF Sr-90 plume. Monitoring results indicated that the highest Sr-90 concentrations are just northwest of the HFBR building, whereas the area of highest tritium concentrations is just south of the HFBR. Verification of the separation of these two plume segments will allow for the installation of additional extraction wells to capture the higher concentration segments of the Sr-90 plume without entraining significant amounts of tritium.
- Eight temporary wells were installed along the Middle Road in the Western South Boundary area to better define the VOC plume in this area of the site. VOC concentrations that were higher than expected (total VOC concentrations up to 120 µg/L) were observed, with the primary contaminants consisting of dichlorodifluoromethane (a freon) and TCA. This contamination is projected to be captured by the Western South Boundary System.
- Because increased Sr-90 levels were observed during 2008 in a sentinel well used to track the downgradient edge of the Sr-90 plume south of the former HWMF, additional characterization of the plume and the installation of new permanent sentinel wells may be required.
- Because there has not been a rebound in contaminant concentrations since the Car-

bon Tetrachloride System was shut down in 2004, a petition for closure of this system will be prepared and submitted to the regulatory agencies in 2009.

- VOC concentrations in Industrial Park East and North Street East monitoring and extraction wells have decreased to levels well below the system capture goals. As a result, a petition for shutdown of this system will be submitted to the regulatory agencies in 2009.

7.7 GROUNDWATER TREATMENT SYSTEMS

The primary mission of the CERCLA program is to operate and maintain groundwater treatment systems and prevent additional groundwater contamination from migrating off site. The cleanup objectives will be met by a combination of active treatment and natural attenuation. The specific cleanup goals are as follows:

- Achieve maximum contaminant levels (MCLs) for VOCs in the Upper Glacial aquifer by 2030
- Achieve MCLs for VOCs in the Magothy aquifer by 2065
- Achieve MCLs for Sr-90 at the BGRR in the Upper Glacial aquifer by 2070
- Achieve MCLs for Sr-90 at the Chemical Holes in the Upper Glacial aquifer by 2040

During 2008, BNL continued to make significant progress in restoring groundwater quality. Figure 7-4 shows the locations of 14 groundwater treatment systems currently in operation. Table 7-5 provides a summary of the amount of VOCs and Sr-90 removed from the aquifer since the start of active remediation in December 1996. During 2008, 220 pounds of VOCs and approximately 3.4 mCi of Sr-90 were removed from the groundwater, and more than 1.5 billion gallons of treated groundwater were returned to the aquifer. To date, 6,117 pounds of VOCs have been removed from the aquifer, and noticeable improvements in groundwater quality are evident in the OU I South Boundary, OU III South Boundary, OU III Industrial Park, OU III Industrial Park East, OU III North Street, OU IV, Building 96, and Carbon Tetrachloride areas. Also to date, two of the treat-




Table 7-5. BNL Groundwater Remediation Systems Treatment Summary for 1997 through 2008.

Remediation System	Start Date	1997-2007		2008	
		Water Treated (Gallons)	VOCs Removed (Pounds) (e)	Water Treated (Gallons)	VOCs Removed (Pounds) (e)
OU I South Boundary	12/1996	3,184,314,000	337	258,000,000	10
OU III HFBR Tritium Plume (a)	05/1997	248,987,000	180	86,000,000	0
OU III Carbon Tetrachloride (d)	10/1999	153,538,075	349	Not in Service	0
OU III Building 96	01/2001	138,297,416	71	34,000,000	13
OU III Middle Road	10/2001	1,267,411,550	741	150,000,000	56
OU III South Boundary	06/1997	3,184,952,850	2,569	135,000,000	60
OU III Western South Boundary	09/2002	602,647,000	49	65,000,000	5
OU III Industrial Park	09/1999	1,364,478,330	1010	128,000,000	24
OU III Industrial Park East	06/2004	287,172,000	33	33,000,000	3
OU III North Street	06/2004	689,122,000	268	180,000,000	21
OU III North Street East	06/2004	428,976,000	20	64,000,000	5
OU III LIPA/Airport	08/2004	846,887,000	235	226,000,000	23
OU IV AS/SVE (b)	11/1997	(c)	35	Decommissioned	0
OU VI EDB	10/2004	471,711,000	(f)	153,000,000	(f)
Total		12,868,485,221	5,897	1,512,000,000	220

Remediation System	Start Date	2003-2007		2008	
		Water Treated (Gallons)	Sr-90 Removed (mCi)	Water Treated (Gallons)	Sr-90 Removed (mCi)
OU III Chemical Holes Sr-90	02/2003	12,404,826	2.59	6,000,000	0.74
OU III BGRR/WCF Sr-90	06/2005	22,151,000	14.15	8,800,000	2.7
Total		34,555,826	16.74	14,800,000	3.44

Notes:

- (a) System was reactivated in late 2007 as a contingency action.
 (b) System was shut down on January 10, 2001 and decommissioned in 2003.
 (c) Air Sparging/Soil Vapor Extraction (AS/SVE) system performance was measured by pounds of VOCs removed per cubic feet of air treated.
 (d) System was shut down and placed in standby mode in August 2004.
 (e) Values are rounded to the nearest whole number.
 (f) Because EDB has only been detected at trace levels in the treatment system influent, no removal of VOCs is reported.

BGRR = Brookhaven Graphite Research Reactor
 EDB = ethylene dibromide
 HFBR = High Flux Beam Reactor
 LIPA = Long Island Power Authority
 OU = Operable Unit
 VOCs = volatile organic compounds
 WCF = Waste Concentration Facility

ment systems have removed approximately 20 mCi of Sr-90. Detailed information on the groundwater treatment systems can be found in SER Volume II, Groundwater Status Report.

REFERENCES AND BIBLIOGRAPHY

Bennett, D., D. Paquette, K. Klaus, and W. Dorsch. 2000. *Brookhaven National Laboratory, Source Water Assessment for Drinking Water Supply Wells*. BNL-52608. Brookhaven National Laboratory, Upton, NY. December 27, 2000.

BNL 2008. *Groundwater Protection Contingency Plan – Response to Unexpected Monitoring Results*. Environmental Monitoring Procedure EM-SOP-309. Brookhaven National Laboratory, Upton, NY. September 2008.

DOE 2003. DOE Order 450.1, *Environmental Protection Program*. U.S. Department of Energy, Washington, DC.

NYSDOH. 2003. *Long Island Source Water Assessment Summary Report*. New York State Department of Health, June 23, 2003.