

Environmental and Waste Management Services Division

BROOKHAVEN
NATIONAL LABORATORY


81 Cornell, Bldg. 120
Upton, NY 11973
Phone 631 344-3477
Fax 631 344-6079
remien@bnl.gov

Managed by Brookhaven Science Associates
for the U.S. Department of Energy

Memo

Date: *August 1, 2005*

To: *Distribution*

From: *Jason Remien* 

Subject: *Renewed Hazardous Substance Bulk Storage Registration Certificate*

The Laboratory has recently received a renewed Hazardous Substance Bulk Storage Registration Certificate.

Copies of the attached certificate must be posted on all of the tanks listed on the certificate. Please ensure that any existing certificates are removed and replaced by the one attached to this memorandum. This registration certificate expires in July 2007. At that time, the CBS inventory will be reevaluated once again and any necessary changes will be made.

If there are any questions, please do not hesitate to contact me at extension 3477.

Attachment: *Hazardous Substance Bulk Storage Registration Certificate*

Distribution: D. Bauer
W. Chaloupka
R. Lee
P. Pohlott
T. Ross

EC83ER.05



Department of Energy

Brookhaven Site Office
P.O. Box 5000
Upton, New York 11973

JUL 29 2005

| | |
|----------------------------------|----------|
| Brookhaven National Laboratory | |
| Environmental & Waste Management | |
| Services Division | |
| Date Recd: | 8-1-2005 |
| File No: | |
| Order To: | |
| | |
| | |
| | |

Mr. George Goode
Brookhaven Science Associates, LLC
Brookhaven National Laboratory
Upton, NY 11973

Dear Mr. Goode:

SUBJECT: CHEMICAL BULK STORAGE REGISTRATION CERTIFICATE

Enclosed please find the subject registration certificate. Please ensure that all terms and conditions are reviewed and adhered to. If you should have any questions, please contact Jerry Granzen of my staff at extension 4089.

Sincerely,


Robert L. Desmarais, Director
Operations Management Division

Enclosure:
As Stated

cc: W. Chaloupka, BSA, w/encl.
R. Lee, BSA, w/encl.
E. Murphy, BSA, w/encl.
J. Remien, BSA, w/encl.



CBS Number
1-000263

New York State Department of Environmental Conservation
CHEMICAL BULK STORAGE CERTIFICATE
625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

Region 1
SUNY Campus Building
40 Loop Road, Stony Brook, NY 11790-2356
(631) 444-0320

| TANK NUMBER | DATE INSTALLED | TANK LOCATION AND TYPE | CAPACITY (GALLONS) | HAZARDOUS SUBSTANCE | % HAZ SUBST | CHEMICAL ABSTRACT # |
|-------------|----------------|-------------------------------|--------------------|---------------------|-------------|---------------------|
| 55501 | | AST - Steel/Carbon Steel/Iron | 750 | | | |
| 624-05 | 04/01/1999 | AST - Plastic | 200 | GALLIUM TRICHLORIDE | 77.00 | 13450-90-3 |
| 624-06 | 04/01/1999 | AST - Plastic | 200 | SODIUM HYPOCHLORITE | 5.00 | 7681-52-9 |
| 624-07 | 09/01/2002 | AST - Plastic | 500 | SODIUM HYPOCHLORITE | 5.00 | 7681-52-9 |
| 624-08 | 09/01/2002 | AST - Plastic | 500 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 634-02 | 12/01/1996 | AST - Steel/Carbon Steel/Iron | 1,000 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 63501 | | AST - Steel/Carbon Steel/Iron | 1,000 | CAUSTIC SODA | 50.00 | 1310-73-2 |
| 63701 | | AST - Steel/Carbon Steel/Iron | 1,200 | CAUSTIC SODA | 50.00 | 1310-73-2 |

OWNER:
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
UPTON, NY 11973

SITE:
BROOKHAVEN NATIONAL LABORATORY
53 BELL AVENUE
UPTON, NY 11973

OPERATOR: BROOKHAVEN SCIENCE
(631) 344-3315
EMERGENCY POLICE HEADQUARTERS
CONTACT: (631) 344-2238


MAILING CORRESPONDENCE:

MICHAEL HOLLAND
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
BUILDING 464
UPTON, NY 11973

ISSUED BY: Acting Commissioner
Denise M. Sheehan
CBS NUMBER: 1-000263
DATE ISSUED: 07/19/2005
EXPIRATION DATE: 07/27/2007
FEE PAID: \$ 625.00

As an authorized representative of the above named facility, I hereby certify that the information on this form is true and correct. Additionally, I recognize that I am responsible for assuring that this facility is in compliance with all sections of ECL Article 40 and 6 NYCRR Parts 595, 596, 597, 598, and 599, not just those cited below:

- The facility must be re-registered if there is a transfer of ownership.
- The facility has maintained its requirements relating to daily, monthly, annual and five year inspections as required by Part 598.7 and has its SPR annually updated as required by Part 598.1(k).
- The Department must be notified within 3 business days prior to adding, replacing, reconditioning, or permanently closing a stationary tank.
- This certificate must be signed and posted on the premises at all times. Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.
- Any person with knowledge of a spill, leak or discharge must report the incident to DEC within two hours (1-800-457-7362).


Signature of Representative/Owner
Date: 7/29/05
Name and Title of Authorized Representative/Owner (Please Print)
Frank Crescenzo, Dep Manager Site Office