

Environmental Protection Division

BROOKHAVEN
NATIONAL LABORATORY

81 Cornell, Bldg. 120
Upton, NY 11973
Phone 631 344-3477
Fax 631 344-6079
remien@bnl.gov

Managed by Brookhaven Science Associates
for the U.S. Department of Energy

Memo

Date: June 15, 2009
To: Distribution
From: Jason Remien
Subject: Renewed Hazardous Substance Bulk Storage Registration Certificate

The Laboratory has recently received a renewed Hazardous Substance Bulk Storage Registration Certificate.

A copy of the attached certificate has been laminated and must be posted on all of the tanks listed on the certificate. Please ensure that any existing certificates are removed and replaced by the one attached to this memorandum. This registration certificate expires in July 2011. At that time, the CBS inventory will be reevaluated once again and any necessary changes will be made.

If there are any questions, please do not hesitate to contact me at extension 3477.

Attachment: Hazardous Substance Bulk Storage Registration Certificate

Distribution: W. Chaloupka, w/ copy of certificate for file
S. Ferrone, w/ laminated copies of certificate for all WTP tanks
R. Lee, w/ copy of certificate for file
T. Ross, w/ copy of certificate for file

File: EC83ER.09



Registered to
ISO 14001



CBS Number
1-000263

New York State Department of Environmental Conservation
CHEMICAL BULK STORAGE CERTIFICATE
625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

Region 1
SUNY Campus Building
40 Loop Road, Stony Brook, NY 11790-2356
(631) 444-0320

| TANK NUMBER | DATE INSTALLED | TANK LOCATION AND TYPE | CAPACITY (GALLONS) | HAZARDOUS SUBSTANCE | % HAZ SUBST | CHEMICAL ABSTRACT # |
|-------------|----------------|-------------------------------|--------------------|---------------------|-------------|---------------------|
| 624-05 | 04/01/1999 | AST - Plastic | 200 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 624-06 | 04/01/1999 | AST - Plastic | 200 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 624-07 | 09/01/2002 | AST - Plastic | 500 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 624-08 | 09/01/2002 | AST - Plastic | 500 | SODIUM HYPOCHLORITE | 15.00 | 7681-52-9 |
| 634-02 | 12/01/1996 | AST - Steel/Carbon Steel/Iron | 1,000 | CAUSTIC SODA | 50.00 | 1310-73-2 |
| 63501 | 01/01/1982 | AST - Steel/Carbon Steel/Iron | 750 | CAUSTIC SODA | 50.00 | 1310-73-2 |

OWNER:
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
UPTON, NY 11973

OPERATOR: BROOKHAVEN SCIENCE
(631) 344-3315

EMERGENCY POLICE HEADQUARTERS CONTACT: (631) 344-2238

ISSUED BY: Commissioner
Alexander B. Grannis
1-000263

DATE ISSUED: 06/02/2009

EXPIRATION DATE: 07/27/2011

FEE PAID: \$ 400.00

SITE:
BROOKHAVEN NATIONAL LABORATORY
53 BELL AVENUE
UPTON, NY 11973

MAILING CORRESPONDENCE:
MICHAEL HOLLAND
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
BUILDING 464
UPTON, NY 11973

As an authorized representative of the above named facility, I hereby certify that the information on this form is true and correct. Additionally, I recognize that I am responsible for assuring that this facility is in compliance with all sections of ECL Article 40 and 6 NYCRR Parts 595, 596, 597, 598, and 599, not just those cited below:

- The facility must be re-registered if there is a transfer of ownership.
- The facility has maintained it's requirements relating to daily, monthly, annual and five year inspections as required by Part 598.7 and has it's SPR annually updated as required by Part 598.1(k).
- The Department must be notified within 3 business days prior to adding, replacing, reconditioning, or permanently closing a stationary tank.
- This certificate must be signed and posted on the premises at all times.

Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.

- Any person with knowledge of a spill, leak or discharge must report the incident to DEC within two hours (1-800-457-7362).

Signature of Representative/ Owner: Michael Holland Date: 6/5/09
Name and Title of Authorized Representative/Owner (Please Print): Michael Holland Site Manager