

# Cryogenic Summary - Testing D1L101 in MAGCOOL

K. C. Wu  
Jan. 02

- Difference between D1L101 & D1L105
- Magnet Temperature and Heat Load
- Tests Performed
- Results
- Problem Encountered
- Lead Precooling
- Summary

# Difference between Testing D1L101 and D1L105

- D1L105
  - Use standard warm bore for RHIC magnet
  - Insufficient super-insulation around magnet end volume
- D1L101
  - Improve super-insulation around magnet end volume
  - Use thermal strip to heat station outer wall of warm bore with 4.5 K cooling

# Magnet Temperature and Heat Load

- Magnet Temperature
  - $\sim 0.05$  K Lower for D1L101 with warm bore evacuated or opened
- Heat Load
  - Appears lower for D1L101
- Effect of bore tube on temperature at MAGCOOL Return Header
  - Increased by  $\sim 0.4$  K (bore tube open compared with evacuated)
  - Unable to determine accurately
  - Seems the same between D1L101 and D1L105


# Tests Performed

- Warm Bore Tube Evacuated
  - Eight Quenches
- Warm Bore Tube Opened
  - Two Quenches
- Warm Bore Tube Removed
  - Two Quenches

# Four groups of tests

- December 12 - 13, 2001
  - Warm bore tube inserted and evacuated
  - Strip heater and natural quenches
- December 13 - 14, 2001
  - Warm bore tube and measuring coil inserted
  - Natural quenches
- December 17, 2001
  - Warm bore tube evacuated
  - Natural quench and 1 hour at 5500 A
- January 18, 2002
  - Warm bore tube removed
  - Ramping 5 times to 7000 A, two Natural quenches

# Quench Current for D1L101




**Quench No. 1 - Strip Heater Quench**  
**No. 2 - 6, 11 - 12, Bore Tube Evacuated**  
**No. 8, Bore Tube Open 1st Day**  
**No. 9, Bore Tube Open 2nd Day**  
**No. 15, Lead Quench**  
**No. 16 - 17, Bore Tube Removed**

# Main Results


- Temperature and heat load in D1L101 are slightly lower than D1L105
- With warm bore inserted, quench current for D1L101 is not higher than D1L105 especially with warm bore open
- With warm bore removed, quench current  $\sim 7400\text{A}$

# Typical operating condition D1L101 - warm bore evacuated




Circ. Loop Makeup ADV500	Subcool Level ADV25	Bypass J.T. ADV14
29	14	12
20.4 pre m e a s u r e m e n t % 12.15 5.0 MAN	100% l e v e l % 79.8 75.0 AUTO	20.4 p r e s s u r e m e a s u r e m e n t % atm 12.7 12.5 MAN
PB-- 150 RS-- 10.0 RT-- 0.0	PB-- 100 RS-- 2.0 RT-- 0.1	PB-- 150 RS-- 10.0 RT-- 0.0

OUTLET TEMP TI79






# Condition of D1L101 at 7000 A - warm bore removed



Circ. Loop Makeup ADV500	Subcool Level ADV25	Bypass J.T. ADV14
20.4	100%	20.4
pre	level	pre
ass	level	ass
%	%	atm
11.98	72.5	12.5
5.0	75.0	12.5
MAN	AUTO	MAN
PB-- 150	PB-- 100	PB-- 150
RS-- 10.0	RS-- 2.0	RS-- 10.0
RT-- 0.0	RT-- 0.1	RT-- 0.0

OUTLET TEMP TI79



# Problem Encountered

- Automatic pressure controller on the helium refrigerator failed, operate manually
  - No problem for test
  - Unable to obtain meaningful peak loop pressure and temperature due to uncontrolled venting
- Current Lead Insulator too cold and leak - one incident
  - Suspect precool flow was set too large or too long
  - Re-commissioned after insulator warmup and lead checked, no problem

## Problem Encountered - continue

- On 1/17/02, a by-pass valve on MAGCOOL was left open by unknown reason. Thus the magnet appears very warm when MAGCOOL reached operating temperature. A 1000 Ampere shutoff was performed and found lead flow control inadequate.
- On 1/18, the by-pass valve is closed and cryogenic system becomes normal. Lead pot is colder than previous experience (T11 & T12 ~ 5.3 & 7.3 K). Try ramping without lead precooling, Lead quenched at 3800 A. No problem was observed for the next two quenches using lead precooling.

# Lead Precooling Requirement

- Past experience - temperature at bottom of lead below 5.3 K to avoid quench
- For D1L105 lead  $\sim$  6 and 11 K (.049 g/s flow)
  - Need lead precooling
- For D1L101 with bore tube evacuated  $\sim$  5.25 K (.060 g/s Tare flow)
  - No precooling
- For D1L101 with bore tube open  $\sim$  6 and 11 K (.049 g/s Tare flow)
  - Need lead precooling

# Precooling 7500 A Lead

- When temperature at the bottom of the lead  $> 5.3$  K
- Switch Flow Controller to MANUAL
- Increase lead flow from 0.049 g/s to  $\sim 0.1$  g/s.
- Watch lead temperature
- As soon as lead reach 5.3 K,
  - Switch Flow Controller back to AUTO
  - At the same time, start ramping

# Summary

- Heat load in D1L101 is reduced by improving thermal insulation
- Warm bore tube was heat stationed
- Temperature of D1L101 is slightly less than D1L105
- Quench current for D1L101 is not higher than D1L105, especially with warm bore open
- Current lead insulator freeze in one incident
- Lead re-commissioned without problem
- Warm bore is undergoing 2<sup>nd</sup> design modification
- Without warm bore, ramp D1L101 to 7000 Amp five times
- Operated at 7000 A and Quenched at  $\sim 7400$  A. Without bore tube, 2nd quench is slightly lower than 1st quench due to .046 K higher temperature.