

BROOKHAVEN NATIONAL LABORATORY CLINICAL RESEARCH CENTER POLICY	CRC POLICY 6.6	PAGE 1 OF 1
	PREPARED BY: J. ROWAN	
SUBJECT: CRC Life Safety Management Plan	REVIEWED BY: W. GUNTHER	
	APPROVED BY: H. BENVENISTE	
	EFFECTIVE DATE: 10/11/04	
	REVISION HISTORY: orig. 9/5/02 rev. 10/11/04	

1.0 POLICY

The CRC shall maintain a fire-safe environment of care within all areas where clinical research studies are conducted.

2.0 LIFE SAFETY MANAGEMENT PLAN

To promote a fire-safe environment, the following procedures shall be followed:

2.1 The Central CRC and all satellite facilities shall conduct quarterly fire drills. These drills shall be reported to the Medical Department Drill Coordinator. (Attachment C, CRC Policy 1.2.3).

2.2 The Central CRC and each satellite location shall be inspected by the BNL Fire Safety Group as prescribed by applicable BNL policies and procedures. These inspections shall occur no less than annually and shall include testing of alarm systems and fire extinguishers.

2.3 Each CRC location shall have appropriate life safety equipment as prescribed by applicable laws and regulations.

2.4 The Central CRC and each satellite facility shall conduct Tier 1 inspections. Any fire safety concerns and/or other deficiencies noted shall be immediately reported to the Building Manager for resolution.

The only official copy of this file is the one online on the Medical Department website under "Clinical Research Center Policy Manual." Before using a printed copy, verify that it is the most current version by checking the document effective date on the website.