



## Department of Energy

Brookhaven Site Office

P.O. Box 5000

Upton, New York 11973

JAN 21 2020

Mr. Jason Remien  
Brookhaven Science Associates, LLC  
Brookhaven National Laboratory  
Upton, New York 11973

Dear Mr. Remien:

SUBJECT: NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
(NYSDEC) INSPECTION OF FIRE PROTECTION WELL AND APPROVED  
PERMIT

Attached is NYSDEC's summary of their January 13, 2020 well inspection and permit titled, "Approval of Well System and Permit to Operate." Please review the permit and ensure a copy is displayed near the well. This permit expires on July 17, 2026.

If you should have any questions regarding this matter, please contact Jerry Granzen, of my staff, at extension 4089.

Sincerely,

A handwritten signature in black ink, appearing to read "M. Dikeakos".

Maria Dikeakos, Director  
Operations Division

Attachment:  
NYSDEC Letter and Well Permit

cc: C. Seniuk, SC-BHSO  
T. Green, BSA  
M. Kretschmann, BSA  
D. Paquette, BSA

**NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION**

Division of Water, Region 1

SUNY @ Stony Brook, 50 Circle Road, Stony Brook, NY 11790

P: (631) 444-0405 | F: (631) 444-0424

www.dec.ny.gov

January 13, 2020

Department of Energy  
53 Bell Avenue  
Upton, NY 11973

Re: Long Island Well Permit: W 4786  
NYSDEC Well No: S 136962

Dear Permittee:

An inspection of the referenced well, was performed on January 13, 2020. The well was found to be constructed in accordance with the terms and conditions of permit number W 5751.

Enclosed please find a copy of the Approval of Well System and Permit to Operate. A copy of the permit must be displayed by their individual Well. The Long Island Well Permit expiration date is July 17, 2026.

Feel free to call me at (631) 444-0416 if you have any questions.

Sincerely,



David Lengyel  
Environmental Program Specialist



Department of  
Environmental  
Conservation



Department of  
Environmental  
Conservation

### APPROVAL OF WELL SYSTEM AND PERMIT TO OPERATE

Long Island Well Permit No: W-4786

NYSDEC Well No: S-136962

**OWNER**

Department of Energy

**ADDRESS**

53 Bell Avenue, Upton, NY, 11973

**LOCATION**

Brookhaven National Laboratory, Upton, NY 11973

**DEPTH**

54 Feet

**DIAMETER CASINGS**

8 Inches

**DIAMETER SCREEN**

8 Inches

**PUMP**

Submersible

OF

500

Gallons Per Minute Capacity

**WATER TO BE USED FOR**

Irrigation

**SPECIAL CONDITIONS**

See L.I. Well Permit W-4786

**DRILLER**

Delta Well and Pump

All construction has been completed in accordance with the provision of Permit(s) W-4786 and the system may be operated subject to the terms thereof.

Department of Environmental Conservation  
Albany, New York

1/13/2020

Date

POST THIS NOTICE NEAR WELL