



CBS Number
1-000263

New York State Department of Environmental Conservation
CHEMICAL BULK STORAGE CERTIFICATE

Region 1
Office of Spill Prevention & Response
50 Circle Road, SUNNY@Stony Brook
Stony Brook, NY 11790-3409 (631)444-0320

625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

TANK NUMBER	DATE INSTALLED	TANK LOCATION AND TYPE	CAPACITY (GALLONS)	HAZARDOUS SUBSTANCE	% HAZ SUBST	CHEMICAL ABSTRACT #
624-05	04/01/1999	AST - Plastic	200	sodium hypochlorite	15.00	7681-52-9
624-06	04/01/1999	AST - Plastic	200	sodium hypochlorite	15.00	7681-52-9
624-07	09/01/2002	AST - Plastic	500	sodium hypochlorite	15.00	7681-52-9
624-08	09/01/2002	AST - Plastic	500	sodium hypochlorite	15.00	7681-52-9
634-02	12/01/1996	AST - Steel/Carbon Steel/Iron	1,000	caustic soda	50.00	1310-73-2
635-04	01/10/2012	AST - Steel/Carbon Steel/Iron	750	caustic soda	50.00	1310-73-2

OWNER:
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
UPTON, NY 11973

SITE:
BROOKHAVEN NATIONAL LABORATORY
53 BELL AVENUE
UPTON, NY 11973

OPERATOR: BROOKHAVEN SCIENCE
(631) 344-3315
EMERGENCY POLICE HEADQUARTERS CONTACT: (631) 344-2238

MAILING CORRESPONDENCE:

ISSUED BY: Commissioner
Joe Martens
CBS NUMBER: 1-000263
DATE ISSUED: 06/25/2015
EXPIRATION DATE: 07/27/2017
FEE PAID: \$ 400.00

FRANK CRESCENZO
U. S. DEPARTMENT OF ENERGY
53 BELL AVENUE
BUILDING 464
UPTON, NY 11973

As an authorized representative of the above named facility, I hereby certify that the information on this form is true and correct. Additionally, I recognize that I am responsible for assuring that this facility is in compliance with all sections of ECL Article 40 and 6 NYCRR Parts 595, 596, 597, 598, and 599, not just those cited below:
-- The facility must be re-registered if there is a transfer of ownership.
-- The facility has maintained it's requirements relating to daily, monthly, annual and five year inspections as required by Part 598.7 and has its SPR annually updated as required by Part 598.1(k).
-- The Department must be notified within 3 business days prior to adding, replacing, reconditioning, or permanently closing a stationary tank.
-- This certificate must be signed and posted on the premises at all times. Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.
-- Any person with knowledge of a spill, leak or discharge must report the incident to DEC within two hours (1-800-457-7362).

Signature of Representative/Owner
Frank Crescenzo
Date *7/2/15*