



*Sewage Treatment Plant operator and staff conducting monitoring activities.*

# Chapter 5

# Water Quality



## Wastewater generated from operations at Brookhaven National Laboratory (BNL) is treated at the Sewage Treatment Plant (STP) before it is discharged to nearby groundwater recharge basins.

Some wastewater may contain very low levels of radiological, organic, or inorganic contaminants. Monitoring, pollution prevention, and vigilant operation of treatment facilities ensure that these discharges comply with all applicable regulatory requirements and that the public, employees, and the environment are protected.

Analytical data for 2024 shows that the average gross alpha and beta activity levels in the STP discharge (Station EA, Outfall 001) were within the typical range of historical levels and were well below New York State Drinking Water Standards (NYSDWS). Tritium (H-3) was detected above the minimum detectable concentration (MDC) in the STP discharge in September 2024; no cesium-137 (Cs-137), strontium-90 (Sr-90), or other gamma-emitting nuclides attributable to Laboratory operations were detected. Non-radiological monitoring of the STP effluent showed that all organic and inorganic parameters were within State Pollutant Discharge Elimination System (SPDES) effluent limits or other applicable standards.

The average concentrations of gross alpha and beta activity in stormwater and cooling water discharged to recharge basins were within typical ranges and no gamma-emitting radionuclides were detected. Disinfection by-products continue to be detected at low concentrations above the minimum detection limit (MDL) in discharges to recharge basins due to the use of chlorine and bromine for the control of algae and bacteria in potable and cooling water systems. Inorganics (e.g., metals) were detected; however, their presence is due primarily to sediment runoff in stormwater discharges.

Radiological data from Peconic River surface water sampling show that the average concentrations of gross alpha activity were indistinguishable from background. Gross beta activity from on-site locations were higher than control locations, however all detected levels were below the applicable NYSDWS. No gamma-emitting radionuclides attributable to Laboratory operations were detected either upstream or downstream of the former STP outfall, and H-3 was not detected above MDCs in any of the surface water samples.

### 5.1

## Surface Water Monitoring Program

In addition to monitoring discharges to surface waters under the SPDES program described in Chapter 3, BNL routinely monitors surface water quality (including radionuclides) as part of its site Surveillance Program.


Although discharges of treated wastewater from the Laboratory's STP into the headwaters of the Peconic River ceased in October 2014, the Laboratory continues to monitor surface water at several locations along the Peconic River to assess the impact that site operations may have on surface water quality.

On-site monitoring station HY is located upstream of all Laboratory operations and data provides information on the background water quality of the Peconic River for comparison to other sampling points that may show impact from Laboratory operations (see Figure 5-1). The Carmans River is monitored as a geographic control location for comparative purposes, as it is not affected by operations at BNL and is not connected to the Peconic River watershed. On the Laboratory site, the Peconic River is an intermittent, groundwater-fed stream.



Off-site flow occurs only after periods of sustained precipitation and a concurrent rise in the water table, typically in the spring. The Peconic River did have a period of off-site flow after heavy rains during the spring in 2024. The fluctuating cycles with periods of flow and no-flow are indicative of the combined influences of precipitation and groundwater. The cycles can sometimes occur over short periods of time, but low groundwater levels often result in several years where no or little flow occurs.

Monitoring data continues to indicate no significant variations in water quality throughout the Peconic River system on-site, and pollution prevention efforts at the Laboratory have significantly reduced the risk of accidental releases. The following sections describe BNL's surface water monitoring and surveillance program.




## 5.2

# Sanitary System Effluents

The STP effluent (Outfall 001/Station EA) is a discharge point authorized under BNL's SPDES permit that is issued by the New York State Department of Environmental Conservation (NYSDEC) (Section 3.6.1). Figure 5-2 shows an aerial photo of the STP with discharge of treated STP effluent to nearby groundwater recharge basins (Recharge Basins A-D). The Laboratory's STP treatment process includes three principal steps: 1) aerobic oxidation for secondary removal of biological matter and nitrification of ammonia, 2) secondary clarification, and 3) filtration for final solids removal. Tertiary treatment for nitrogen removal is also provided by controlling the oxygen levels in the aeration tanks. During the aeration process, the oxygen levels are allowed to drop to the point where micro-organisms use nitrate-bound oxygen for respiration, which liberates nitrogen gas and consequently reduces the concentration of nitrogen in the STP discharge.

**Figure 5-2.** An aerial photo of BNL's Sewage Treatment Plant (Recharge Basin Discharge).



Solids separated in the clarifier are pumped to aerobic digesters for continued biological solids reduction and sludge thickening. Once the sludge in the aerobic digester reaches a solids content of 6%, the sludge is sampled to ensure it meets the waste acceptance criteria for disposal at the Suffolk County Department of Public Works Sewage Treatment Facility at Bergen Point, in West Babylon, New York.

Real-time monitoring of the sanitary waste stream for radioactivity, pH, and conductivity occurs at two locations. The first site, MH-192, is approximately one mile upstream of the STP and provides a minimum of 30 minutes to warn the STP operators that wastewater exceeding SPDES limits or BNL administrative effluent release criteria is enroute to the STP. The second monitoring site is at the point where the STP influent enters the treatment process.

Based on the data collected by the real-time monitoring systems, any influent to the STP that may not meet SPDES limits and BNL effluent release criteria can be diverted to two double-lined holding ponds. The total combined capacity of the two holding ponds exceeds six million gallons, or approximately 18 days of flow. Diversion would continue until the influent water quality would allow for the permit limits and release criteria to be met. Wastewater diverted to the holding ponds is tested and evaluated against the requirements for release. If necessary, the wastewater is treated and then reintroduced into the STP at a rate that ensures compliance with SPDES permit limits for non-radiological parameters or BNL effluent release criteria for radiological parameters. In 2024, there were no instances where influent water quality required diversion of wastewater to the holding ponds due to SPDES limits or BNL effluent release criteria. Wastewater is occasionally diverted to allow for optimum operation of the STP.

### 5.2.1 Sanitary System Effluent - Radiological Analyses

Wastewater at the STP is sampled at the inlet to the treatment process, Station DA, and at the STP outfall, Station EA, as shown in Figure 5-2. At each location, samples are collected on a flow-proportional basis; that is, for every 1,000 gallons of water treated, approximately four fluid ounces of sample are collected and composited into a five-gallon collection container. These samples are analyzed weekly for gross alpha and gross beta activity and for H-3. Samples collected from these locations are also composited and analyzed monthly for gamma-emitting radionuclides and Sr-90 (half-life: 29 years).

Although the STP discharge is not used as a direct source of potable water, the Laboratory applies the more stringent Safe Drinking Water Act (SDWA) standards for comparison purposes when monitoring the effluent, in lieu of Department of Energy (DOE) wastewater criteria. Under the SDWA, water standards are based on a 4 mrem (40  $\mu$ Sv) dose limit. The SDWA specifies that no individual may receive an annual dose greater than 4 mrem from radionuclides that are beta or photon emitters, which includes up to 168 individual radioisotopes. BNL performs radionuclide-specific gamma analysis to ensure compliance with this standard. The SDWA annual average gross alpha activity limit is 15 pCi/L, including radium-226 (Ra-226) (half-life: 1,600 years), but excluding radon and uranium. Other SDWA-specified drinking water limits are 20,000 pCi/L for H-3 (half-life: 12.3 years), 8 pCi/L for Sr-90, 5 pCi/L for Ra-226 and Ra-228 (half-life: 5.75 years), and 30  $\mu$ g/L for uranium. Gross alpha and beta activity measurements are used as a screening tool for detecting the presence of radioactivity.

Table 5-1 shows the monthly gross alpha and beta activity data and H-3 concentrations for the STP influent and effluent during 2024. Annual average gross alpha and beta activity levels in the STP effluent were  $1.2 \pm 0.4$  pCi/L and  $5.0 \pm 0.8$  pCi/L, respectively. Both gross alpha and gross beta average concentrations were higher than those measured at the Carmans River control location (HH) reported in Table 5-5; however, they were well below the SDWA standards of 15 pCi/L and 50 pCi/L respectively, that are used for comparison purposes. H-3 was detected above the MDC in the discharge of the STP (EA, Outfall 001) in September 2024 with the average concentration being  $98.3 \pm 66.5$  pCi/L, well below the SDWA standard of 20,000 pCi/L. Conservative estimates of total release based on H-3, gross-alpha, and gross-beta in millicuries is provided in Table 5-1. In 2024, there were no gamma-emitting nuclides detected in the STP effluent.

**Table 5-1.** Tritium and Gross Activity in Water at the Sewage Treatment Plant for 2024.

		Flow	Tritium (pCi/L)		Gross Alpha (pCi/L)		Gross Beta (pCi/L)	
		(liters)	max.	avg.	max.	avg.	max.	avg.
January	influent	2.98E+07	< 437	< MDC	< 6.5	< MDC	4.3 ± 1.1	3.4 ± 0.8
	effluent	2.92E+07	< 429	< MDC	< 4.4	< MDC	5.1 ± 1.4	3.8 ± 0.9
February	influent	1.52E+07	< 486	< MDC	< 7.7	< MDC	8.8 ± 2.2	4.9 ± 2.6
	effluent	1.70E+07	< 485	< MDC	< 5.7	< MDC	6.8 ± 1.8	3.7 ± 2.2
March	influent	1.90E+07	< 506	< MDC	< 5.0	< MDC	4.0 ± 1.8	2.3 ± 1.2
	effluent	2.37E+07	< 507	< MDC	< 6.2	< MDC	4.5 ± 2.6	4.0 ± 0.5
April	influent	2.13E+07	< 469	< MDC	< 4.0	< MDC	6.4 ± 2.2	4.1 ± 1.8
	effluent	2.53E+07	< 471	< MDC	< 5.0	< MDC	9.6 ± 2.9	5.0 ± 2.4
May	influent	1.92E+07	< 491	< MDC	7.4 ± 2.1	< MDC	27.2 ± 3.4	10.4 ± 11.0
	effluent	1.50E+07	< 494	< MDC	< 3.0	< MDC	9.9 ± 2.0	4.4 ± 3.8
June	influent	2.78E+07	< 509	< MDC	< 5.5	< MDC	10.5 ± 4.7	7.2 ± 3.5
	effluent	2.45E+07	< 511	< MDC	< 5.4	< MDC	10.3 ± 4.5	6.5 ± 3.0
July	influent	3.08E+07	< 515	< MDC	< 8.4	< MDC	14.1 ± 1.8	8.2 ± 5.4
	effluent	3.05E+07	< 510	< MDC	< 4.6	< MDC	13.6 ± 2.2	7.4 ± 4.7
August	influent	3.22E+07	< 463	< MDC	3.1 ± 1.3	< MDC	12.5 ± 3.0	5.7 ± 4.5
	effluent	2.96E+07	< 466	< MDC	< 4.2	< MDC	12.8 ± 3.1	6.5 ± 3.7
September	influent	2.38E+07	1128.9 ± 302.0	696.6 ± 281.7	< 4.5	< MDC	9.2 ± 2.8	5.0 ± 2.8
	effluent	2.78E+07	1018.8 ± 298.1	564.3 ± 313.3	< 4.8	< MDC	6.3 ± 3.5	4.3 ± 1.4
October	influent	1.81E+07	< 482	< MDC	< 3.4	< MDC	5.2 ± 1.7	4.0 ± 1.2
	effluent	2.05E+07	< 480	< MDC	< 3.4	< MDC	4.6 ± 1.8	3.3 ± 1.3
November	influent	1.61E+07	< 491	< MDC	< 5.5	< MDC	7.7 ± 1.8	5.3 ± 1.7
	effluent	1.75E+07	< 478	< MDC	< 3.3	< MDC	10.8 ± 2.1	5.8 ± 3.4
December	influent	2.10E+07	< 548	< MDC	< 4.2	< MDC	4.9 ± 1.7	3.9 ± 1.0
	effluent	2.23E+07	< 533	< MDC	< 4.1	< MDC	7.0 ± 1.9	4.9 ± 1.4
Annual Avg.	influent			78.9 ± 74.3		1.5 ± 0.5		5.3 ± 1.1
	effluent			98.3 ± 66.5		1.2 ± 0.4		5.0 ± 0.8
Total Release		2.83E+08		28 mCi (a)		0.3 mCi		1.5 mCi
Average MDC (pCi/L)				442.3		3.5		3.4
SDWA Limit (pCi/L)				20000		15		(b)

Notes:

All values are reported with a 95% confidence interval.

To convert values from pCi to Bq, divide by 27.03.

MDC=minimum detected concentration

SDWA = Safe Drinking Water Act

(a) The total released value for tritium is a conservative calculation that is based on an average of the 95% confidence interval positive averages as estimates of monthly average release concentrations. The majority of the effluent samples showed average concentrations less than zero.

(b) The drinking water standards were changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in 2003. As gross beta activity does not identify specific radionuclides, a dose equivalent cannot be calculated for the values in the table.



## 5.2.2 Sanitary System Effluent – Non-radiological Analyses

Monitoring of the STP effluent for volatile organic compounds (VOCs), inorganics, and anions is conducted as part of the SPDES Compliance Program, which is discussed in further detail in Chapter 3.

## 5.3

### Process-specific Wastewater

Wastewater that may contain constituents above SPDES permit limits or ambient water quality discharge standards must be held by the generating facility and characterized to determine the appropriate means of disposal. The analytical results are compared with the appropriate discharge limit, and the wastewater is only released to the sanitary system if the volume and concentration of contaminants in the discharge would not jeopardize the quality of the STP effluent and subsequently, potentially impact groundwater quality (BNL 2025).

The Laboratory's SPDES permit includes requirements for quarterly sampling and analysis of process-specific wastewater discharged from metal-cleaning operations in Building 498 and cooling tower discharges from Building 902. These operations are monitored for contaminants such as metals, cyanide, VOCs, and semi-VOCs. In 2024, there were no wastewater discharges from Building 498. Analyses of Building 902 wastewater showed that, although several operations contributed contaminants (principally metals) to the STP influent in concentrations exceeding SPDES-permitted levels, these discharges did not affect the quality of the STP effluent.

Process wastewaters that are not expected to be of consistent quality and are not routinely generated are held for characterization before release to the sanitary system. The process wastewaters typically include purge water from groundwater sampling, wastewater from cleaning of heat exchangers, wastewater generated as a result of restoration activities, and other industrial wastewaters.

To determine the appropriate disposal method, samples are analyzed for contaminants specific to the process, and the concentrations are compared to the SPDES effluent limits and BNL's effluent release criteria (BNL 2025). If the concentrations are within limits, authorization for sewer system discharge is granted; if not, alternate means of disposal are used. Any waste that contains elevated levels of hazardous or radiological contaminants in concentrations that exceeded Laboratory effluent release criteria are sent to the BNL Waste Management Facility for proper management and off-site disposal.

## 5.4


### Recharge Basins


Recharge basins are used for the discharge of “clean” wastewater, including once-through cooling water, stormwater runoff, and cooling tower blowdown. These wastewaters are suitable for direct replenishment of the groundwater aquifer. Figure 5-3 shows the locations of the Laboratory's discharges to recharge basins (also called “outfalls” under BNL's SPDES permit). Figure 5-4 presents an overall schematic of potable water use at the Laboratory, and how much of this water is discharged to the 12 on-site recharge basins:

- Basin HZ receives stormwater and cooling water discharges from Bldg. 902.
- Basins HN, HT-W, and HT-E receive once-through cooling water discharges generated at the Alternating Gradient Synchrotron (AGS), Linear Accelerator, and Relativistic Heavy Ion Collider (RHIC), as well as cooling tower blowdown and stormwater runoff.

- Basin HS receives predominantly stormwater runoff, once-through cooling water from Building 555 (Chemistry Department), and minimal cooling tower blowdown from the Computational Science Initiative facility (Bldg. 725).
- Basin HX receives Water Treatment Plant filter backwash water.
- Basin HO receives cooling water discharges from the AGS and stormwater runoff from the area surrounding the High Flux Beam Reactor (HFBR) (Bldg. 750).

**Figure 5-3.** BNL Recharge Basin/Outfall Locations.



**Figure 5-4.** Schematic of Potable Water Use and Flow at BNL.**Site Level Water Balance**  
Daily Average (kgal)

Several other recharge areas are used exclusively for discharging stormwater runoff. These areas include Basin HW near the National Synchrotron Light Source II (NSLS-II) site, Basin CSF at the Central Steam Facility (CSF), and Basin HW-M at the Former Hazardous Waste Management Facility (FHWMF). Recharge Basins HP and RAV are used for discharge of treated water from the groundwater remediation systems and are monitored under BNL's Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) equivalency permits.

Each of the recharge basins is a permitted point-source discharge under the Laboratory's SPDES permit and equivalency permits under the CERCLA program. Where required by the permit, the basins are equipped with a flow monitoring station, allowing for weekly recordings of flow rates. The specifics of the SPDES compliance monitoring program are provided in Chapter 3.

To supplement the monitoring program, samples are also routinely collected and analyzed under BNL's Environmental Surveillance Program for radioactivity, VOCs, metals, and anions. During 2024, water samples were collected semi-annually from all the basins listed above except for recharge Basin HX at the Water Treatment Plant (due to previously documented non-impact to groundwater from plant operations) and a recharge basin at the FHWMF (due to absence of operations at the FHWMF that could lead to the contamination of runoff).

5.4.1 Recharge Basins – Radiological Analyses

Discharges to recharge basins with the potential for radiological contamination were sampled semi-annually and analyzed for gross alpha and beta activity, gamma-emitting radionuclides, and H-3. The results are summarized in Table 5-2. Gross alpha values were below the MDCs and gross beta activity ranged from non-detect to  $9.41 \pm 2.02$  pCi/L. Low-level detections of beta activity are attributable to naturally occurring radionuclides, such as potassium-40 (K-40) (half-life:  $1.3\text{E}+09$  years). No gamma-emitting nuclides attributable to BNL operations or H-3 were detected in any discharges to recharge basins.

5.4.2 Recharge Basins – Non-Radiological Analyses

During 2024, discharge samples were collected semi-annually for water quality parameters, metals, and VOCs. Field-measured parameters (e.g., pH, conductivity, and temperature) were routinely monitored and recorded. The water quality and metals analytical results are summarized in Tables 5-3 and 5-4, respectively. The non-radiological analytical results are compared to groundwater discharge standards promulgated under Title 6 of the New York Codes, Rules, and Regulations (NYCRR), Part 703.6.

Low concentrations of disinfection byproducts were periodically detected above the MDLs in discharges to several of the basins throughout the year. Sodium hypochlorite and bromine, used to control bacteria in the drinking water and algae in cooling towers, can break down to various products including bromoform, chloroform, bromodichloromethane, and dibromochloromethane. Concentrations were above the 5 µg/L MDL for bromoform at Basin HT-W, the highest value being 5.4 µg/L, below the 50 µg/L drinking water standard. All other values were below the 5 µg/L MDL.

The analytical data presented in Table 5-3 show that, for 2024, the concentrations of all analytes were within effluent standards. Historically, chlorides are found to be higher in samples collected during the winter and are attributed to road salt used to control snow and ice buildup. High chloride values, which can also result in high conductivity, continued to persist in results in 2024. The data in Table 5-4 show that all parameters complied with the respective water quality or groundwater discharge standards.

Table 5-2. Radiological Analysis of Samples From On-Site Recharge Basins (2024).

Basin		Gross Alpha	Gross Beta	Tritium
		(pCi/L)		
No. of Samples		2	2	2
HN	Max.	< 1.80	$2.56 \pm 0.80$	< 448
	Avg.	< MDC	$1.57 \pm 1.94$	< MDC
HO	Max.	< 2.08	$0.98 \pm 0.68$	< 454
	Avg.	< MDC	$0.89 \pm 0.60$	< MDC
HS	Max.	< 1.80	$1.00 \pm 0.73$	< 448
	Avg.	< MDC	$0.96 \pm 0.66$	< MDC
HT-E	Max.	< 17.00	$7.25 \pm 4.25$	< 454
	Avg.	< MDC	$7.09 \pm 3.36$	< MDC
HT-W	Max.	< 1.75	$1.67 \pm 0.67$	< 448
	Avg.	< MDC	$1.16 \pm 0.55$	< MDC
HW	Max.	< 6.86	$9.41 \pm 2.02$	< 444
	Avg.	< MDC	$5.20 \pm 1.38$	< MDC
HZ	Max.	< 2.26	$2.72 \pm 0.81$	< 431
	Avg.	< MDC	$1.73 \pm 0.65$	< MDC
SDWA Limit		15	(a)	20,000

Notes:  
See Figure 5-3 for recharge basin/outfall locations.  
All values reported with a 95% confidence interval.  
To convert values from pCi to Bq, divide by 27.03.  
(a) The drinking water standard was changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in 2003. As gross beta activity does not identify specific radionuclides, a dose equivalent of this value cannot be calculated.  
MDC = minimum detected concentration  
SDWA = Safe Drinking Water Act

**Table 5-3.** Water Quality Data for On-site Recharge Basins (2024).

Analyte		Recharge Basin								NYSDEC Effluent Standard	Typical MDL
		HN (RHIC)	HO (AGS/HFBR)	HS (S)	HT-W (Linac)	HT-E (AGS)	HW (S)	CSF (S)	HZ (S)		
No. of Samples		2	2	2	2	2	2	2	2		
pH (SU)	Min.	7.6	8.0	7.2	8.2	7.5	7.2	7.3	7.3	6.5 - 8.5	NA
	Max.	7.8	8.3	8.0	8.3	8.4	7.5	7.7	8.1		
Conductivity (µS/cm)	Min.	317	340	75	403	1000	87	80	404	SNS	NA
	Max.	1212	364	404	738	6482	496	498	479		
	Avg.	764.5	352	239.5	570.5	3741	291.5	289	441.5		
Temperature (Deg. C)	Min.	8.1	14.4	7.0	6.8	12.0	6.2	6.0	13.3	SNS	NA
	Max.	22.1	24.7	21.8	26.7	26.6	21.2	22.2	25.6		
	Avg.	15.1	19.6	14.4	16.8	19.3	13.7	14.1	19.5		
Dissolved Oxygen (mg/L)	Min.	8.5	8.4	8.0	7.9	9.8	8.0	8.7	7.6	SNS	NA
	Max.	9.4	9.8	10.6	9.8	10.0	9.9	10.1	9.8		
	Avg.	8.9	9.1	9.3	8.8	9.9	9.0	9.4	8.7		
Chlorides (mg/L)	Min.	19	56	6.8	43	270	10	2.8	73	SNS	0.2
	Max.	67	76	130	59	2400	800	1500	74		
	Avg.	43	66	68.4	51	1335	405	751.4	73.5		
Sulfate (mg/L)	Min.	4.8	11	3.6	8.2	22	3.4	2.0	10	500	0.5
	Max.	8.0	13	9.8	12	39	7.0	8.9	14		
	Avg.	6.4	12	6.7	10.1	30.5	5.2	5.5	12.0		
Nitrate as Nitrogen (mg/L)	Min.	0.3	0.5	0.2	0.4	0.2	0.3	0.3	1.1	10	0.1
	Max.	0.4	0.6	0.5	0.6	0.6	0.4	0.3	1.4		
	Avg.	0.4	0.6	0.3	0.5	0.4	0.3	0.3	1.3		

## Notes:

See Figure 5-3 for recharge basin/outfall locations.

S = stormwater

AGS = Alternating Gradient Synchrotron

HFBR = High Flux Beam Reactor

Linac = Linear Accelerator

MDL = minimum detection limit

NA = not applicable

NYSDEC = New York State Department of Environmental Conservation

RHIC = Relativistic Heavy Ion Collider

SNS = effluent standard not specified

**Table 5-4.** Metals Analysis of Water Samples From BNL On-Site Recharge Basins (2024).

Recharge Basin										NYSDEC Effluent LIMIT or AWQS	Typical MDL
Metal	HO (AGS)		HT-E (AGS)		HT-W (Linac)		HZ (Stormwater)				
Total (T) or Filtered (F)	T	F	T	F	T	F	T	F			
No. of Samples	2	2	2	2	2	2	2	2			
Ag Silver (µg/L)	Min.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	50	1
	Max.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0		
	Avg.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0		
Al Aluminum (µg/L)	Min.	45	15	87	8.3	41	19	47	23	2000	15
	Max.	150	19	260	24	190	24	240	33		
	Avg.	97.5	17	173.5	16.2	115.5	21.5	143.5	28		
As Arsenic (µg/L)	Min.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	50	2
	Max.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
	Avg.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
Ba Barium (µg/L)	Min.	38	40	100	100	29	32	29	31	2000	0.8
	Max.	41	42	110	110	42	39	54	41		
	Avg.	39.5	41	105	105	35.5	35.5	41.5	36		
Be Beryllium (µg/L)	Min.	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	SNS	0.3
	Max.	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3		
	Avg.	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3		
Cd Cadium (µg/L)	Min.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	10	0.5
	Max.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5		
	Avg.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5		
Co Cobalt (µg/L)	Min.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	5	1
	Max.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0		
	Avg.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0		
Cr Chromium (µg/L)	Min.	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	100	3
	Max.	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0		
	Avg.	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0		
Cu Copper (µg/L)	Min.	1.0	2.0	6.0	4.8	2.5	1.4	12	11	1000	1
	Max.	5.5	2.2	10	4.8	9.6	1.7	75	27		
	Avg.	3.25	2.1	8.0	4.8	6.1	1.55	43.5	19		
Fe Iron (µg/L)	Min.	< 200	< 200	420	< 200	< 200	< 200	< 200	< 200	600	200
	Max.	440	< 200	580	200	300	< 200	340	< 200		
	Avg.	320	< 200	500	< 200	250	< 200	270	< 200		

(continued on next page)



**Table 5-4.** Metals Analysis of Water Samples From BNL On-Site Recharge Basins (2024) (*concluded*).

Recharge Basin										NYSDEC Effluent LIMIT or AWQS	Typical MDL
Metal		HO (AGS)		HT-E (AGS)		HT-W (Linac)		HZ (Stormwater)			
Total (T) or Filtered (F)		T	F	T	F	T	F	T	F		
No. of Samples		2	2	2	2	2	2	2	2		
<b>Hg</b> Mercury (µg/L)	Min.	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	1.4	0.2
	Max.	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2		
	Avg.	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2		
<b>Mn</b> Manganese (µg/L)	Min.	< 3.0	< 3.0	23	16	< 3.0	< 3.0	4.2	3.1	600	1.5
	Max.	21	< 3.0	85	84	8.4	< 3.0	16	5.4		
	Avg.	12	< 3.0	54	50	5.7	< 3.0	10.7	4.3		
<b>Na</b> Sodium (mg/L)	Min.	32	32	180	190	23	25	43	46	SNS	0.07
	Max.	42	44	1300	1300	35	36	48	51		
	Avg.	37	38	740	745	29	30.5	45.5	48.5		
<b>Ni</b> Nickel (µg/L)	Min.	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	200	10
	Max.	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10		
	Avg.	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10		
<b>Pb</b> Lead (µg/L)	Min.	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	1.8	< 1.0	50	0.5
	Max.	< 1.0	< 1.0	2.2	< 1.0	1.4	< 1.0	19	5.0		
	Avg.	< 1.0	< 1.0	1.6	< 1.0	1.2	< 1.0	10.4	3.0		
<b>Sb</b> Antimony (µg/L)	Min.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	6	2
	Max.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
	Avg.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
<b>Se</b> Selenium (µg/L)	Min.	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	20	5
	Max.	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0		
	Avg.	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0		
<b>Tl</b> Thallium (µg/L)	Min.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	SNS	0.5
	Max.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5		
	Avg.	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5		
<b>V</b> Vanadium (µg/L)	Min.	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	SNS	2
	Max.	< 2.0	< 2.0	2.3	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
	Avg.	< 2.0	< 2.0	2.15	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0		
<b>Zn</b> Zinc (µg/L)	Min.	< 10	< 10	61	17	18	< 10	43	23	5000	10
	Max.	< 10	< 10	81	67	58	23	54	40		
	Avg.	< 10	< 10	71	42	38	16.5	48.5	31.5		

## Notes:

See Figure 5-3 for recharge basin/outfall locations.

AGS = Alternating Gradient Synchrotron

AWQS = Ambient Water Quality Standards

Linac = Linear Accelerator

MDL = minimum detection limit

NYSDEC = New York State Department of Environmental Conservation

SNS = Standard Not Specified



### 5.4.3 Stormwater Management

Stormwater at BNL is managed by collecting runoff from paved surfaces, roofs, and other impermeable surfaces and directing it to recharge basins via underground piping and above-grade vegetated swales. Recharge Basin HS receives most of the stormwater runoff from the central, developed portion of the Laboratory site. Basins HN, HZ, HT-W, and HT-E receive runoff from the Collider-Accelerator complex. Basin HO receives runoff from the area surrounding the HFBR. Basin CSF receives runoff from the CSF area and along Cornell Avenue east of Renaissance Road. Basin HW receives runoff from the NSLS-II site, and HW-M receives runoff from the fenced area at the FHWMF.

Stormwater runoff at the Laboratory typically has elevated levels of inorganics (e.g., metals) and has a low pH. The inorganics are attributable to high sediment content in stormwater (inorganics occur naturally in native soil). In an effort to further improve the quality of stormwater runoff on-site, BNL has formal procedures for managing and maintaining outdoor work and storage areas. The requirements include covering of equipment and materials (e.g., road salt storage and bins/containers with potential to leak residual oils or any other hazardous materials) to prevent contact with stormwater, conducting an aggressive maintenance and inspection program, implementing erosion control measures during soil disturbance activities, and restoring these areas when operations cease.

Basin sediment sampling is conducted on a five-year testing cycle to ensure these discharges comply with regulatory requirements. Basin sediments were sampled in 2022 and the next sampling event will occur in 2027.

## 5.5

### Peconic River Surveillance

Several locations are monitored along the Peconic River to assess the overall water quality of the river and assess any impact from BNL operations. Sampling points along the Peconic River are identified in Figure 5-1. In total, four stations (two upstream and two downstream of the former STP discharge) were sampled in 2024. A sampling station along the Carmans River (HH) was also monitored as a geographic control location not affected by Laboratory operations or located within the Peconic River watershed. The following locations were monitored for radiological and non-radiological parameters:

Upstream sampling station:

- HY, on-site, immediately east of William Floyd Parkway
- HV, on-site, just east of the 10 o'clock experimental hall in the RHIC Ring, radiological only

Downstream sampling stations:

- HM-S, on-site, at east firebreak south of main stem of Peconic
- HQ, on-site, at east boundary of BNL

Control location:

- HH, Carmans River

### 5.5.1 Peconic River – Radiological Analyses

During 2024, radionuclide analyses were performed on surface water samples collected from the four Peconic River sampling locations and the Carmans River control location. Stations HY and HV on the Peconic River allow for radiological assessment of potential RHIC impacts and no other contributions from potential BNL operations enter the river until the tributary monitoring at HM-S. HQ sampling station is the final monitoring location before the river flows off-site and, when flowing, is representative of all surface water flows from the BNL site.

**Table 5-5.** Radiological Results for Surface Water Samples Collected Along the Peconic and Carmans Rivers (2024).

Sampling Station		Gross Alpha	Gross Beta	Tritium	Strontium-90
		----- (pCi/L) -----			
<b>HY</b> (headwaters) on site, west of the RHIC ring.	N	2	2	2	2
	Max.	< 1.11	3.17 ± 0.80	< 440	< 0.63
	Avg.	< MDC	2.52 ± 0.75	< MDC	< MDC
<b>HV</b> (headwaters) on site, inside the RHIC ring.	N	1	1	1	NS
	Max.	< 1.19	< 0.92	< 400	NS
	Avg.	-	-	-	NS
<b>HM-S</b> tributary, on-site	N	1	1	1	1
	Max.	< 1.22	< 0.92 ± 0.56	< 381	< 0.46
	Avg.	-	-	-	-
<b>HQ</b> BNL site boundary	N	1	1	1	1
	Max.	< 1.39	< 1.81 ± 1.32	< 445	< 0.77
	Avg.	-	-	-	-
<b>Carmans River</b> HH control Location, off-site	N	2	2	2	2
	Max.	< 1.81	< 1.9 ± 1.28	< 374	< 0.75
	Avg.	< MDC	< MDC	< MDC	< MDC
<b>SDWA Limit</b>		<b>15</b>	<b>(a)</b>	<b>20,000</b>	<b>8</b>

**Notes:**

See Figure 5-1 sampling station locations.

All values reported with a 95% confidence interval.

To convert values from pCi to Bq, divide by 27.03.

MDC=minimum detected concentration

N = number of samples analyzed

NS = sample not taken due to dry conditions

RHIC = Relativistic Heavy Ion Collider

SDWA = Safe Drinking Water Act

(a) The drinking water standard was changed from 50 pCi/L (concentration based) to 4 mrem/yr (dose based) in 2003. Because gross beta activity does not identify specific radionuclides, a dose equivalent cannot be calculated for the values in the table.

- = only one sample taken due to dry conditions

In 2024, the Peconic River flow continued to be low. Two samples were able to be taken at the uppermost sampling location HY during or immediately after precipitation. One sample was able to be taken at the remaining three sampling locations, HV, HM-S, and HQ. The radiological data from Peconic River surface water samples are summarized in Table 5-5. Radiological analysis of water samples collected from HY had very low concentrations of gross beta activity that were attributed to natural sources. All other gross beta values were below MDCs, and all detected levels were below the applicable NYSDWS. H-3, gross alpha, and Sr-90 values were below MDCs at all locations on the Peconic and Carmans Rivers.

### 5.5.2 Peconic River – Non-radiological Analyses

River water samples collected in 2024 were analyzed for

water quality parameters (e.g., pH, temperature, conductivity, and dissolved oxygen), anions (e.g., chlorides, sulfates, and nitrates), metals, and VOCs. The analytical data for the Peconic River and Carmans River samples are summarized in Table 5-6 (water quality) and Table 5-7 (metals). No VOCs were found in any samples collected from the Peconic and Carmans Rivers in 2024. Water quality parameters measured at the Peconic River Location (HY) and the Carmans River control location (HH) show that temperature, conductivity, and dissolved oxygen levels were all within applicable NYS standards. Peconic River pH values were lower than the NYS effluent standards. Low pH values are natural on Long Island due to the presence of organic materials (e.g., leaf litter).

Ambient water quality standards (AWQS) for metallic elements are based on their solubility state.

Certain metals are only biologically available to aquatic organisms if they are in a dissolved or ionic state, whereas other metals are toxic in any form (i.e., dissolved and particulate combined). In 2024, the BNL monitoring program continued to assess water samples for both the dissolved and particulate form. Dissolved concentrations were determined by filtering the samples prior to acid preservation and analysis.

Examination of the total (i.e., particulate form) metals data showed that aluminum, copper, iron, and lead were present in concentrations at Peconic River locations that exceeded New York State Ambient Water Quality Standards (NYS AWQS). Aluminum was detected at concentrations exceeding the NYS AWQS at locations on the Peconic River for unfiltered and filtered samples. Iron was detected at both Peconic and Carmans River sampling stations at concentrations that were at or slightly exceeding the NYS AWQS in unfiltered samples, with dissolved levels falling below NYS AWQS; iron and aluminum are found in high concentrations in native Long Island soil and, for iron, at high levels in groundwater. Copper and lead at concentrations greater than the NYS AWQS were found in samples collected at stations HY and HM-S (lead only) on the Peconic River. Filtration of samples reduced concentration for some metals to below the detection level, suggesting that suspended sediment was responsible for metals in those samples.

**Table 5-6.** Water Quality Analytical Results for Surface Water Samples Collected Along the Peconic and Carmans Rivers (2024).

Analyte		Peconic River Locations			Carmans River HH (Control)	NYSDEC Effluent Standard	Typical MDL
		HY	HM-S	HQ			
No. of Samples		2	1	1	2		
pH (SU)	Min.	5.6	-	-	7.9	6.5 - 8.5	NA
	Max.	5.8	6.3	6.2	8.0		
	Avg.	5.7	-	-	7.9		
Conductivity (µS/cm)	Min.	4.0	-	-	109.0	SNS	NA
	Max.	55.0	53	50	247.0		
	Avg.	29.5	-	-	178.0		
Temperature (deg C)	Min.	10.3	-	-	13.2	SNS	NA
	Max.	13.5	12.2	13.5	13.2		
	Avg.	11.9	-	-	13.2		
Dissolved Oxygen (mg/L)	Min.	9.8	-	-	9.6	SNS	NA
	Max.	10.5	10.1	7.4	9.9		
	Avg.	10.2	-	-	9.7		
Chlorides (mg/L)	Min.	2.1	-	-	39.6	250	0.67
	Max.	12.0	3.7	5.1	41.8		
	Avg.	7.1	-	-	40.7		
Sulfate (mg/L)	Min.	0.7	-	-	12.6	250	0.5
	Max.	4.0	7.3	4.8	13.0		
	Avg.	2.4	-	-	12.8		
Nitrate as Nitrogen (mg/L)	Min.	< MDL	-	-	2.1	10	0.1
	Max.	< MDL	< MDL	< MDL	2.9		
	Avg.	< MDL	-	-	2.5		

**Notes:**

See Figure 5-1 for monitoring locations.

HY = Peconic River headwaters, on site, east of Wm Floyd Pkwy

HQ = Peconic River on-site at east boundary

HM-S = Peconic River tributary at east firebreak

HH = Carmans River control location, off-site

MDL = minimum detection limit

NYSDEC = New York State Department of Environmental Conservation

SNS = effluent standard not specified

- = only one sample taken due to dry conditions



**Table 5-7.** Metals Analytical Results for Surface Water Samples Collected Along the Peconic and Carmans Rivers (2024).

Peconic River Locations										NYSDEC AWQS (a)	Typical MDL
Metal		HY		HM-S		HQ		Carmans River HH (Control)			
Total (T) or Dissolved (D)		T	D	T	D	T	D	T	D		
No. of Samples		2	2	1	1	1	1	2	2		
Ag Silver (µg/L)	Min.	< 1	< 1	-	-	-	-	< 1	< 1	0.1	1
	Max.	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1		
	Avg.	< 1	< 1	-	-	-	-	< 1	< 1		
Al Aluminum (µg/L)	Min.	370	26	-	-	-	-	< 15	< 15	100	15
	Max.	390	340	540	350	239	249	< 15	< 15		
	Avg.	380	183	-	-	-	-	< 15	< 15		
As Arsenic (µg/L)	Min.	2	< 2	-	-	-	-	< 2	< 2	150	2
	Max.	3.3	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	Avg.	2.7	< 2	-	-	-	-	< 2	< 2		
Ba Barium (µg/L)	Min.	7.4	4	-	-	-	-	38.4	35.2	SNS	1
	Max.	12	7.7	6.8	7.7	6.9	7.2	43.4	42.2		
	Avg.	9.7	5.9	-	-	-	-	40.9	38.7		
Be Beryllium (µg/L)	Min.	< 1	< 1	-	-	-	-	< 1	< 1	11	1
	Max.	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1		
	Avg.	< 1	< 1	-	-	-	-	< 1	< 1		
Cd Cadmium (µg/L)	Min.	< 1	< 1	-	-	-	-	< 1	< 1	1.1	1
	Max.	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1		
	Avg.	< 1	< 1	-	-	-	-	< 1	< 1		
Co Cobalt (µg/L)	Min.	< 2.5	< 2.5	-	-	-	-	< 2.5	< 2.5	5	2.5
	Max.	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5	< 2.5		
	Avg.	< 2.5	< 2.5	-	-	-	-	< 2.5	< 2.5		
Cr Chromium (µg/L)	Min.	< 1.5	< 1.5	-	-	-	-	< 1.5	< 1.5	34	1.5
	Max.	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5		
	Avg.	< 1.5	< 1.5	-	-	-	-	< 1.5	< 1.5		
Cu Copper (µg/L)	Min.	1.8	1.9	-	-	-	-	< 5	< 5	4	5
	Max.	4.1	3.7	1.1	1.9	6.32	5.6	< 5	< 5		
	Avg.	3.0	2.8	-	-	-	-	< 5	< 5		
Fe Iron (µg/L)	Min.	0.2	< 0.2	-	-	-	-	0.2	< 0.2	0.3	0.2
	Max.	0.6	< 0.2	< 0.2	< 0.2	0.5	0.05	0.3	< 0.2		
	Avg.	0.4	< 0.2	-	-	-	-	0.2	< 0.2		
Hg Mercury (µg/L)	Min.	< 0.2	< 0.2	-	-	-	-	< 0.2	< 0.2	0.2	0.2
	Max.	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2		
	Avg.	< 0.2	< 0.2	-	-	-	-	< 0.2	< 0.2		

(continued on next page)

**Table 5-7.** Metals Analytical Results for Surface Water Samples Collected Along the Peconic and Carmans Rivers (2024) (concluded).

Peconic River Locations										NYSDEC AWQS (a)	Typical MDL
Metal		HY		HM-S		HQ		Carmans River HH (Control)			
Total (T) or Dissolved (D)		T	D	T	D	T	D	T	D		
No. of Samples		2	2	Dry	Dry	Dry	Dry	2	2		
<b>Mn</b> Manganese (µg/L)	Min.	12	< 1.5	-	-	-	-	50.4	41.3	<b>SNS</b>	<b>1.5</b>
	Max.	42	43	18	47	24.9	26.6	58	61.4		
	Avg.	27	23	-	-	-	-	54.2	51.4		
<b>Na</b> Sodium (mg/L)	Min.	4.1	2.7	-	-	-	-	25.6	24.8	<b>SNS</b>	<b>0.1</b>
	Max.	6.2	6.5	2.2	7	4.7	5.29	25.9	25.4		
	Avg.	5.2	4.6	-	-	-	-	25.8	25.1		
<b>Ni</b> Nickel (µg/L)	Min.	< 10	< 10	-	-	-	-	< 10	< 10	<b>23</b>	<b>10</b>
	Max.	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10		
	Avg.	< 10	< 10	-	-	-	-	< 10	< 10		
<b>Pb</b> Lead (µg/L)	Min.	1.6	< 0.5	-	-	-	-	< 0.5	< 0.5	<b>0.1</b>	<b>0.5</b>
	Max.	2.6	1.4	1.2	1.8	< 0.5	< 0.5	< 0.5	< 0.5		
	Avg.	1.8	1.2	-	-	-	-	< 0.5	< 0.5		
<b>Sb</b> Antimony (µg/L)	Min.	< 3.5	< 3.5	-	-	-	-	< 3.5	3.8	<b>SNS</b>	<b>3.5</b>
	Max.	< 3.5	< 3.5	< 3.5	< 3.5	< 3.5	< 3.5	3.7	4.4		
	Avg.	< 3.5	< 3.5	-	-	-	-	3.6	4.1		
<b>Se</b> Selenium (µg/L)	Min.	< 1.5	< 1.5	-	-	-	-	< 1.5	< 1.5	<b>4.6</b>	<b>1.5</b>
	Max.	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5	< 1.5		
	Avg.	< 1.5	< 1.5	-	-	-	-	< 1.5	< 1.5		
<b>Tl</b> Thallium (µg/L)	Min.	< 0.6	< 0.6	-	-	-	-	< 0.6	< 0.6	<b>8</b>	<b>0.6</b>
	Max.	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6	< 0.6		
	Avg.	< 0.6	< 0.6	-	-	-	-	< 0.6	< 0.6		
<b>V</b> Vanadium (µg/L)	Min.	< 2	< 2	-	-	-	-	< 2	< 2	<b>14</b>	<b>2</b>
	Max.	2.4	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	Avg.	2.2	< 2	-	-	-	-	< 2	< 2		
<b>Zn</b> Zinc (µg/L)	Min.	11	*	-	-	-	-	< 10	< 10	<b>37</b>	<b>10</b>
	Max.	31	*	< 10	< 10	< 10	< 10	< 10	< 10		
	Avg.	20.5	*	-	-	-	-	< 10	< 10		

Notes:

See Figure 5-1 sampling station locations.

AWQS = Ambient Water Quality Standards

MDL = minimum detection limit

SNS = effluent standard not specified for these elements in Class C surface waters

(a) NYS AWQS for Class C surface waters

- = only one sample taken due to dry conditions

\* = sample taken but not usable



## References and Bibliography

BNL. 2025. Standards Based Management System Subject Area: Liquid Effluents. Brookhaven National Laboratory, Upton, NY. January 2025.

NYCRR Part 703.6. Title 6. 2023 Surface Water and Groundwater Quality Standards and Groundwater Effluent Limitations. New York State Department of Environmental Conservation. Albany, NY



*Zeke's Pond within the Upton Ecological Research Reserve at BNL.*