

**Table 3.2.2-3
OU III Building 96 2013 Extraction Well Pumping Rates**

2013 BNL Groundwater Status Report

Operable Unit III - Pump and Treat					
BUILDING 96 SYSTEM - Groundwater Withdrawal and ReInjection (gpm)					
BNL Well No.	095-151	095-153	095-155	095-157	BUILDING
Extraction Well	RTW-1	RTW-2	RTW-3	RTW-4	96
Screen Int.					
Influent					
elevation (ft. msl)	+34 to +24	+26 to +16	+26 to +16	+23 to +13	
depth (feet)	48 to 58	48 to 58	48 to 58	48 to 58	
Effluent					
elevation (ft. msl)	+57 to +47	+49 to +39	+49 to +39	+46 to +36	Monthly
depth (feet)	25 to 35	25 to 35	25 to 35	25 to 35	Total
January	11	16	32	0	59
February	2	5	17	0	24
March	26	26	32	0	85
April	26	22	31	0	78
May	28	14	34	0	75
June	34	30	33	0	97
July	32	32	32	0	95
August	34	37	34	0	105
September	27	32	31	0	90
October	34	32	34	0	99
November	31	34	35	0	100
December	18	16	30	0	64
Annual Average (gpm)	25	25	31	0	81

Notes:

Source: EM Field Engineer

ft. msl = Elevation in feet referenced to mean sea level.

Elevations rounded to nearest foot

gpm - gallons per minute