

National Synchrotron Light Source II, Brookhaven National Laboratory			
Doc No. <b>PS-C-XFD-PRC-005</b>	Author: <b>B. Heneveld</b>	Effective Date: <b>13Nov2015</b> Review Frequency: <b>3 yrs</b>	Version <b>3</b>
Title: <b>Beamline Enclosures and Cryogen Fill Station ODH Monitoring and Alarm System Certification and Inspection</b>			<b>Technical</b>

**Attachment A**

**Beamline Enclosures and Cryogen Fill Station ODH Monitoring and Alarm System Inspection Data Sheet**

**Enclosure/Cryogen Fill Station** 17 BM A

- Monitor display indicating 20.4% – 21.4% oxygen Yes  No
- Monitor is securely mounted Yes  No
- Diffusion port is free of dust or other material accumulation Yes  No
- All enable lights are illuminated Yes  No
- All conduit containing power and alarm cables are intact and secure Yes  No
- Zirconium O<sub>2</sub> sensor is within 10 years of service Yes  No

Maintenance activities to be performed (if required):

Initial Place into service

---



---



---



---

**Note:** Signatures below indicate that the inspection has been completed.

Inspection Reason: <u>Place into service</u>	Inspection Result: <input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	
Inspection Date: <u>4/22/16</u>	Start Time: <u>10:45</u>	Finish Time: <u>10:55</u>
Inspector: <u>Brian Heneveld</u>	Assistant: <u>Gabrielle Stuve</u>	
Inspector Signature: <u>[Signature]</u>	Assistant Signature: <u>[Signature]</u>	
Technical Authority: <u>Steve LaManna</u>	Technical Authority Signature: <u>[Signature]</u>	