

National Synchrotron Light Source II, Brookhaven National Laboratory			
Doc No. PS-C-XFD-PRC-005	Author: B. Heneveld	Effective Date: 13Nov2015 Review Frequency: 3 yrs	Version 3
Title: Beamline Enclosures and Cryogen Fill Station ODH Monitoring and Alarm System Certification and Inspection			Technical

Attachment A

Beamline Enclosures and Cryogen Fill Station ODH Monitoring and Alarm System Inspection Data Sheet

Enclosure/Cryogen Fill Station 12 ID A

- Monitor display indicating 20.4% – 21.4% oxygen Yes No
- Monitor is securely mounted Yes No
- Diffusion port is free of dust or other material accumulation Yes No
- All enable lights are illuminated Yes No
- All conduit containing power and alarm cables are intact and secure Yes No
- Zirconium O₂ sensor is within 10 years of service Yes No

Maintenance activities to be performed (if required):

None

Note: Signatures below indicate that the inspection has been completed.

Inspection Reason: <u>Recertification</u>	Inspection Result: <input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	
Inspection Date: <u>10/18/16</u>	Start Time: <u>8:55</u>	Finish Time: <u>9:00</u>
Inspector: <u>Brian Heneveld</u>	Assistant: <u>Gabrielle Stove</u>	
Inspector Signature: <u>Brian Heneveld</u>	Assistant Signature: <u>[Signature]</u>	
Technical Authority: <u>Steve LaMara</u>	Technical Authority Signature: <u>[Signature]</u>	