

**Brookhaven National Laboratory**  
**Plant Engineering - E&CS Division**  
**Engineering Change Notice Form**

**PROJECT:** CCWF II

**JOB No.** 11705

**ECN Title:** Parapet Detail

**ECN No.** 26

Affected Documents: A-504

Requested Change (Attach sketch if applicable): Interface parapet between new and existing roofing at all levels. Provide new wider continuous 24 GA. cleat, treated wood blocking, counter flashing, base flashing, metal studs, DensGlass and curb insulation as per attached sketch.

Requested by: E. W. Howell

Date: 01/19/10

Resolution: See the attached sketch.

Approvals: A/E or Proj. Eng.: B. Kimble



Date: 03/05/10

Project Coordinator: A. Raphael



Date: 03/05/10

Manager:

Date:

Contractor shall take the following action:

- Await change order from P&PM
- Proceed with change as described
- Provide cost proposal for change as described

Distribution: E. W. Howell

Giffels

PPM

E&U


MPO

O&M

DOE

NSLS II

ECN File



504S PARAPET DETAIL  
 A-302 N.T.S.