

# E.W. Howell Co., LLC

113 Crossways Park Drive

# REQUEST FOR INFORMATION

No. 00010

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

**TITLE:** Detail 302D/SC-101

**DATE:** 8/14/2009

**PROJECT:** BNL CCWF-II

**JOB:**

**TO:** Attn: Allan Raphael  
Brookhaven National Laboratory  
Brookhaven Sciences Associates, LLC  
Project Modernization Office  
Upton, NY 11973-5000

**STARTED:**

**COMPLETED:**

**REQUIRED:** 8/21/2009

## WORK

**IMPACT:** Unknown

## SCHEDULE

**IMPACT:** Unknown

## COST

**IMPACT:** Unknown

## QUESTION:

August 14, 2009  
Detail 302D/SC-101

Please clarify the embedment depth for the 3/4" anchors on detail 302D/SC-101.

CC: File, Bill Harrison


## PROPOSED SOLUTION:

## ANSWER:

Embedment depth for 3/4" dia, HIS carbon steel rod, Hilti RE-500 epoxy anchors = 8 1/4"

S. Muddappa  
Giffels Partnership  
08-24-09

Requested By: E.W. Howell Co., LLC

Signed:   
Lauren Bergin

Date: 8/14/09