

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

REQUEST FOR INFORMATION

No. 00017

Phone: 516-921-7100

Fax: 516-921-7920

TITLE: Sleeve Collars

DATE: 9/11/2009

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Alan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 9/18/2009

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

9/11/2009

Sleeve Collars

Please see detail 500D/A-300 and 500G/A-300.

Please provide model and manufacturer for the neoprene collars.

Please clarify the need for fire stopping on 500G if the steel closure plate is not rated

CC: File

PROPOSED SOLUTION:

ANSWER:

The wall is not fire rated and caulk does not have to be a fire rated type tested system.

A couple of manufacturers of neoprene sheet flashing are Gaco Western and Carlisle. It generally comes in rolls of varying widths. An alternative would be an EPDM type pipe flashing boot made by RFS, Del-tite or Carrington (but may not come large enough).

John D. [Signature]

Requested By: E.W. Howell Co., LLC

Date: _____ 9-18-09

Signed: _____
Lauren Bergin