

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

REQUEST FOR INFORMATION

No. 00042

TITLE: Alternate Lighting Routing

DATE: 3/9/2010

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Alan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:
COMPLETED:
REQUIRED: 3/16/2010

WORK IMPACT: Unknown

SCHEDULE IMPACT: Unknown

COST IMPACT: Unknown

QUESTION:

3/9/2010
Alternate Lighting Routing

On contract drawing ES-101 it shows the site lighting conduit penetrating the foundation wall. On contract drawing EP-400 it calls for this conduit to be continued to an existing lighting contractor on the operating floor. HincK proposes to run this conduit underground adjacent to the new Building 600B and enter the building at one of the ductbank windows and then rise up the chase with the other conduits. Please advise if this is acceptable.

CC: Bill Harrison, George Santorilla, File

PROPOSED SOLUTION:

~~CONTRACTOR'S PROPOSED/ALTERNATE CONDUIT RUN IS ACCEPTABLE TO GIFFELS PROVIDED THE UNDERGROUND LIGHTING CONDUIT IS INSTALLED CLOSE TO BLUE COOKS WEST WALL. PROVIDE DEDICATED CONDUIT RUN FOR THE OUTDOOR POLE MOUNTED LIGHT FIXTURES FROM THE LIGHTING CONTRACTOR TO LIGHT FIXTURES. OBTAIN OWNER'S APPROVAL PRIOR TO IMPLEMENTATION.~~

ANSWER:

B. Mojica
GIFFELS 3/9/10

N/A See ECN 28
3/17/10
AR

Requested By: E.W. Howell Co., LLC

Date: _____

Signed: _____
Hans Laros