

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

REQUEST FOR INFORMATION

No. 00071

TITLE: Locker Room Fin Tube

DATE: 9/10/2010

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Alan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 9/17/2010

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

9/10/10
Locker Room Fin Tube

There are 2 pieces of fin tube required for the locker room and utility room in the plant. The specifications say they are to be wall to wall, yet the schedule has a specific length. Please clarify what is required.

Also, attached is the color chart, please select a color option for the fin tube.

PROPOSED SOLUTION:

ANSWER:

THE INTENT IS TO HAVE THE FINNED TUBE COVER GO WALL TO WALL. THE FINNED TUBE LENGTHS ARE TO BE AS SCHEDULED.

W. HARRISON GIFFELS/ISJ GROUP 9-13-10

The color for the fin tube is Cameo white (WB-3).

Requested By: E.W. Howell Co., LLC

Signed: _____
Hans Laros

Date: 



Sterling Commercial Hydronic Color Selector


Color Selector (CS-5)

**Standard Enamel Finishes For
Commercial Finned-Tube, Convector, and Cabinet Unit Heaters**

These are color reproductions and approximate the actual colors as closely as possible.
The actual color you see may depend on the monitor, colors, and screen resolution on the computer you are viewing this on.
Special Colors can be provided. Please consult the factory for price and samples.



SB-1
Light Grey



WB-3
Cameo White




SB-7
Soft Dove



WB-2
Eggshell



SB-6
Deluxe Beige



P-1
White



DB-5
Black



DB-1
Dark Bronze